

NO.WRD/WDXI/SDIII/TECH/W.F.01/2023/2023-24/251

. Dated:-28/11/2023

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall near St. Cruz chapel at Shirvodem in Margao Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.01/20/2023						231.11		No. 332/ SD III/ WD III/ WRD/23-24/ <b>305</b> . <b>DATED: 20-10-2023</b>
	F.01/21/2023	14-10-2023	13-11-2023	Retaining wall foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.01/22/2023						226.67		
1.2	F.01/23/2023						235.56		
	F.01/24/2023	14-10-2023	13-11-2023	Retaining wall foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.01/25/2023						222.22		
2.1	F.01/25/2023						235.56		
	F.01/26/2023	17-10-2023	14-11-2023	Retaining wall 1st Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.01/27/2023						217.78		
2.2	F.01/28/2023						235.56		
	F.01/29/2023	17-10-2023	14-11-2023	Retaining wall 1st Lift	1.2.4	210 kg/cm2	226.67	229.63	do
	F.01/29/2023						226.67		
3	F.01/30/2023						231.11		
	F.01/31/2023	19-10-2023	16-11-2023	Retaining wall final lift	1.2.4	210 kg/cm2	217.78	223.70	do
	F.01/32/2023						222.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**