

NO: WRD /WD XI / SD III/ TECH/W.F. 04-Oct-2023/256 / 2023-24

Dated:05/12/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the RHS bank of nallah to protect side bank in Village Codar of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.04/18/2023						235.56		No. WRD/WD XI/SD IV/ F.CF/438/2023-24. DATED: 08-11-2023
	F.04/19/2023	2/11/2023	30-11-2023	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.04/20/2023						222.22		
2	F.04/21/2023						231.11		
	F.04/22/2023	4/11/2023	2/12/2023	Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.04/23/2023						231.11		
3	F.04/24/2023						235.56		
	F.04/25/2023	6/11/2023	4/12/2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.04/26/2023						226.67		
4	F.04/27/2023						235.56		
	F.04/28/2023	7/11/2023	5/12/2023	Foundation	1.2.4	210 kg/cm2	231.11	232.59	do
	F.04/29/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER