

NO.WRD/WDXI/SDIII/TECH/W.F.149/2021/2022-23/ 26. Dated:- 03-11-2022

GOVERNMENT OF GOA  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Flood mitigation measures to the banks of nallah at Deulmol- Shirvoi, Quepem in ward No.4 of Quepem Muncipal Council in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.149/06/2021						151.11		No. WRD/WD XII/SD V/
	F.149/07/2021	27-09-2022	4/10/2022	Superstructure	1.2.4	140 kg/cm2	146.67	148.15	F.15/145/2022-23.
	F.149/08/2021						146.67		<b>DATED: 04-10-2022.</b>
2	F.149/09/2021						151.11		
	F.149/10/2021	27-09-2022	4/10/2022	Superstructure	1.2.4	140 kg/cm2	142.22	146.67	do
	F.149/11/2021						146.67		
3	F.149/12/2021						151.11		
	F.149/13/2021	28-09-2022	6/10/2022	Superstructure	1.2.4	140 kg/cm2	146.67	149.63	do
	F.149/14/2021						151.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**