

NO: WRD /WD XI / SD III/ TECH/W.F. 03- Oct- 2023/270 / 2023-24

Dated:15/12/23

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.03/61/2023						146.67		No. WRD/SD V/WD XII/ F.70/233/2023-24. DATED: 21-11-2023
	F.03/62/2023	15-11-2023	22-11-2023	Foundation (R.H.S)	1.2.4	140 kg/cm2	151.11	146.67	
	F.03/63/2023						142.22		
2	F.03/64/2023						146.67		do
	F.03/65/2023	16-11-2023	23-11-2023	Foundation (R.H.S)	1.2.4	140 kg/cm2	142.22	148.15	
	F.03/66/2023						155.56		
3	F.03/67/2023						151.11		do
	F.03/68/2023	17-11-2023	24-11-2023	1st Lift (R.H.S)	1.2.4	140 kg/cm2	137.78	145.19	
	F.03/69/2023						146.67		
4	F.03/70/2023						146.67		do
	F.03/71/2023	18-11-2023	25-11-2023	1st Lift (R.H.S)	1.2.4	140 kg/cm2	142.22	145.19	
	F.03/72/2023						146.67		
5	F.03/73/2023						155.56		do
	F.03/74/2023	19-11-2023	26-11-2023	1st Lift & 2nd Lift (R.H.S)	1.2.4	140 kg/cm2	142.22	149.63	
	F.03/75/2023						151.11		
6	F.03/76/2023						146.67		do
	F.03/77/2023	20-11-2023	27-11-2023	2nd Lift (R.H.S)	1.2.4	140 kg/cm2	155.56	146.67	
	F.03/78/2023						137.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER