

NO: WRD /WD XI / SD III/ TECH/W.F. 14-Oct-2023/274 / 2023-24

Dated:18/12/23

GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to storm water drain in Sy.No.5/3 at Zariwada, Tivrem in V.P. Tivrem - Orgao in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 14/29/2023						111.11		No.WRD/WDXI/SDIV/ F.CF/455/2023-24. <b>DATED: 20-11-2023</b>
	F. 14/30/2023	15-11-2023	13-12-2023	In Foundation	1.3.6	100 kg/cm2	106.67	109.63	
	F. 14/31/2023						111.11		
1.2	F. 14/32/2023						115.56		
	F. 14/33/2023	15-11-2023	13-12-2023	In Foundation	1.3.6	100 kg/cm2	111.11	111.11	do
	F. 14/34/2023						106.67		
2.1	F. 14/35/2023						111.11		
	F. 14/36/2023	16-11-2023	14-12-2023	In Foundation	1.3.6	100 kg/cm2	111.11	112.59	do
	F. 14/37/2023						115.56		
2.2	F. 14/38/2023						115.56		
	F. 14/39/2023	16-11-2023	14-12-2023	In Foundation	1.3.6	100 kg/cm2	120.00	115.56	do
	F. 14/40/2023						111.11		
3.1	F. 14/41/2023						106.67		
	F. 14/42/2023	17-11-2023	15-12-2023	In Foundation	1.3.6	100 kg/cm2	115.56	111.11	do
	F. 14/43/2023						111.11		
3.2	F. 14/44/2023						102.22		
	F. 14/45/2023	17-11-2023	15-12-2023	In Foundation	1.3.6	100 kg/cm2	111.11	109.63	do
	F. 14/46/2023						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER