

NO.WRD/WDXI/SDIII/TECH/W.F.13/2023/2023-24/278

. Dated:-20/12/23

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall in Sy.No. 10/1 Portem Vaddem near Ganapati Visarjan Shed V.P. Vaddem Curdi in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.13/06/2023						231.11		No.WRD/SD I/ WDXII/ F.47/226/2023-24. DATED: 22-11-2023
	F.13/07/2023	11/11/2023	11/12/2023	Foundation Ch.0.00m to 15.00m LHS	1.2.4	210 kg/cm2	240.00	234.07	
	F.13/08/2023						231.11		
1.2	F.13/09/2023						235.56		do
	F.13/10/2023	11/11/2023	11/12/2023	Foundation Ch.0.00m to 15.00m LHS	1.2.4	210 kg/cm2	226.67	231.11	
	F.13/11/2023						231.11		
2.1	F.13/12/2023						231.11		do
	F.13/13/2023	13-11-2023	11/12/2023	Foundation Ch.15.00m to 30.00m LHS	1.2.4	210 kg/cm2	222.22	232.59	
	F.13/14/2023						244.44		
2.2	F.13/15/2023						226.67		do
	F.13/16/2023	13-11-2023	11/12/2023	Foundation Ch.15.00m to 30.00m LHS	1.2.4	210 kg/cm2	235.56	229.63	
	F.13/17/2023						226.67		
3.1	F.13/18/2023						226.67		do
	F.13/19/2023	14-11-2023	12/12/2023	Foundation Ch.0.00m to 15.00m RHS	1.2.4	210 kg/cm2	231.11	226.67	
	F.13/20/2023						222.22		
3.2	F.13/21/2023						235.56		do
	F.13/22/2023	14-11-2023	12/12/2023	Foundation Ch.0.00m to 15.00m RHS	1.2.4	210 kg/cm2	231.11	228.15	
	F.13/23/2023						217.78		
4.1	F.13/24/2023						222.22		do
	F.13/25/2023	15-11-2023	13-12-2023	Foundation Ch.15.00m to 22.00m RHS	1.2.4	210 kg/cm2	235.56	232.59	
	F.13/26/2023						240.00		
4.2	F.13/27/2023						240.00		do
	F.13/28/2023	15-11-2023	13-12-2023	Foundation Ch.15.00m to 22.00m RHS	1.2.4	210 kg/cm2	231.11	234.07	
	F.13/29/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall in Sy.No. 10/1 Portem Vaddem near Ganapati Visarjan Shed V.P. Vaddem Curdi in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.13/30/2023						235.56		No.WRD/SD I/ WDXII/ F.47/226/2023-24. DATED: 22-11-2023
	F.13/31/2023	16-11-2023	14-12-2023	1st Lift Ch.0.00 m to 20.00 m LHS	1.2.4	210 kg/cm2	231.11	229.63	
	F.13/32/2023						222.22		
5.2	F.13/33/2023						231.11		
	F.13/34/2023	16-11-2023	14-12-2023	1st Lift Ch.0.00 m to 20.00 m LHS	1.2.4	210 kg/cm2	226.67	228.15	do
	F.13/35/2023						226.67		
6.1	F.13/36/2023						235.56		
	F.13/37/2023	17-11-2023	15-12-2023	1st Lift Ch.20.00 m to 30.00 m LHS	1.2.4	210 kg/cm2	235.56	231.11	do
	F.13/38/2023			& 0.00 m to 10.00 RHS			222.22		
6.2	F.13/39/2023						240.00		
	F.13/40/2023	17-11-2023	15-12-2023	1st Lift Ch.20.00 m to 30.00 m LHS	1.2.4	210 kg/cm2	231.11	229.63	do
	F.13/41/2023			& 0.00 m to 10.00 RHS			217.78		
7.1	F.13/42/2023						235.56		
	F.13/43/2023	18-11-2023	16-12-2023	1st Lift Ch. 10.00 m to 20.00 m RHS	1.2.4	210 kg/cm2	217.78	226.67	do
	F.13/44/2023			& 2nd Lift 0.00 m to 25.00 m LHS			226.67		
7.2	F.13/45/2023						231.11		
	F.13/46/2023	18-11-2023	16-12-2023	1st Lift Ch. 10.00 m to 20.00 m RHS	1.2.4	210 kg/cm2	231.11	228.15	do
	F.13/47/2023			& 2nd Lift 0.00 m to 25.00 m LHS			222.22		
8.1	F.13/48/2023						235.56		
	F.13/49/2023	20-11-2023	18-12-2023	2nd Lift Ch.25.00 m to 30.00 m LHS	1.2.4	210 kg/cm2	222.22	226.67	do
	F.13/50/2023			& 2nd Lift 0.00 m to 20.00 m RHS			222.22		
8.2	F.13/51/2023						235.56		
	F.13/52/2023	20-11-2023	18-12-2023	2nd Lift Ch.25.00 m to 30.00 m LHS	1.2.4	210 kg/cm2	226.67	228.15	do
	F.13/53/2023			& 2nd Lift 0.00 m to 20.00 m RHS			222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER