

NO.WRD/WDXI/SDIII/TECH/W.F.40/2024/2024-25/278

. Dated:-08/01/25

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing random rubble masonry and other works connecting 2 No. CD's between Ch. 9.80 km to Ch. 10.00 Km of SIP canal.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.40/12/2024						120.00		No. WRD/WD X/ SD I/
	F.40/13/2024	10/12/2024	7/1/2025	All works upto plinth level	1.3.6	100 kg/cm2	111.11	115.56	F. 55A/ 190 /2024-25.
	F.40/14/2024						115.56		DATED: 12-12-2024.
2	F.40/15/2024						111.11		
	F.40/16/2024	11/12/2024	8/1/2025	All works upto plinth level	1.3.6	100 kg/cm2	115.56	114.08	
	F.40/17/2024						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER