

NO.WRD/WDXI/SDIII/TECH/W.F.24/2024/2024-25/279

. Dated:-10/01/25

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to tanks (6 Nos)at Karmane Querim in V.P. Querim in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.24/06/2024						231.11		No. WRD/WD XI/ SD IV/ W.F. 420/476/2024-25. DATED: 13-12-2024.
	F.24/07/2024	6/12/2024	3/1/2025	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	
	F.24/08/2024						217.78		
1.2	F.24/09/2024						226.67		
	F.24/10/2024	6/12/2024	3/1/2025	For Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F.24/11/2024						235.56		
2.1	F.24/12/2024						222.22		
	F.24/13/2024	9/12/2024	6/1/2025	For Foundation	1.2.4	210 kg/cm2	231.11	232.59	do
	F.24/14/2024						244.44		
2.2	F.24/15/2024						235.56		
	F.24/16/2024	9/12/2024	6/1/2025	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F.24/17/2024						231.11		
3.1	F.24/18/2024						235.56		
	F.24/19/2024	11/12/2024	8/1/2025	For Foundation	1.2.4	210 kg/cm2	217.78	228.15	do
	F.24/20/2024						231.11		
3.2	F.24/21/2024						226.67		
	F.24/22/2024	11/12/2024	8/1/2025	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	
	F.24/23/2024						222.22		
4.1	F.24/24/2024						235.56		
	F.24/25/2024	13-12-2024	10/1/2025	For Foundation	1.2.4	210 kg/cm2	222.22	228.15	do
	F.24/26/2024						226.67		
4.2	F.24/27/2024						235.56		
	F.24/28/2024	13-12-2024	10/1/2025	For Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.24/29/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER