

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah near Shree Paikdev temple at Bondoi of Village Naqueri in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.152/57/2021						217.78		No. WRD/WD II/SD V/
	F.152/58/2021	3/10/2022	31-10-2022	Foundation	1.2.4	210 kg/cm2	222.22	222.22	F.70/151/2022-23.
	F.152/59/2021						226.67		DATED: 10-10-2022.
1.2	F.152/60/2021						222.22		
	F.152/61/2021	3/10/2022	31-10-2022	Foundation	1.2.4	210 kg/cm2	222.22	223.70	do
	F.152/62/2021						226.67		
1.3	F.152/63/2021						217.78		
	F.152/64/2021	3/10/2022	31-10-2022	Foundation	1.2.4	210 kg/cm2	222.22	220.74	do
	F.152/65/2021						222.22		
1.4	F.152/66/2021						222.22		
	F.152/67/2021	3/10/2022	31-10-2022	Foundation	1.2.4	210 kg/cm2	222.22	223.70	do
	F.152/68/2021						226.67		
1.5	F.152/69/2021						222.22		
	F.152/70/2021	3/10/2022	31-10-2022	Foundation	1.2.4	210 kg/cm2	222.22	222.22	do
	F.152/71/2021						222.22		
2.1	F.152/72/2021						217.78		
	F.152/73/2021	4/10/2022	1/11/2022	1st Lift	1.2.4	210 kg/cm2	213.33	216.30	do
	F.152/74/2021						217.78		
2.2	F.152/75/2021						217.78		
	F.152/76/2021	4/10/2022	1/11/2022	1st Lift	1.2.4	210 kg/cm2	222.22	219.26	do
	F.152/77/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah near Shree Paikdev temple at Bondoi of Vilage Naqueri in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.3	F.152/78/2021						222.22		No. WRD/WD II/SD V/
	F.152/79/2021	4/10/2022	1/11/2022	1st Lift	1.2.4	210 kg/cm2	217.78	219.26	F.70/151/2022-23.
	F.152/80/2021						217.78		DATED: 10-10-2022.
3.1	F.152/81/2021						226.67		
	F.152/82/2021	5/10/2022	2/11/2022	2nd Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.152/83/2021						226.67		
3.2	F.152/84/2021						222.22		
	F.152/85/2021	5/10/2022	2/11/2022	2nd Lift	1.2.4	210 kg/cm2	226.67	223.70	do
	F.152/86/2021						222.22		
3.3	F.152/87/2021						222.22		
	F.152/88/2021	5/10/2022	2/11/2022	2nd Lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.152/89/2021						226.67		
4.1	F.152/90/2021						217.78		
	F.152/91/2021	6/10/2022	3/11/2022	3rd Lift	1.2.4	210 kg/cm2	222.22	217.78	do
	F.152/92/2021						213.33		
4.2	F.152/93/2021						217.78		
	F.152/94/2021	6/10/2022	3/11/2022	3rd Lift	1.2.4	210 kg/cm2	217.78	219.26	do
	F.152/95/2021						222.22		
5.1	F.152/96/2021						231.11		
	F.152/97/2021	7/10/2022	4/11/2022	4th Lift	1.2.4	210 kg/cm2	235.56	234.08	do
	F.152/98/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah near Shree Paikdev temple at Bondoi of Vilage Naqueri in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.2	F.152/99/2021						231.11		No. WRD/WD II/SD V/
	F.152/100/2021	7/10/2022	4/11/2022	4th Lift	1.2.4	210 kg/cm2	235.56	232.59	F.70/151/2022-23.
	F.152/101/2021						231.11		DATED: 10-10-2022.
6	F.152/102/2021						222.22		
	F.152/103/2021	8/10/2022	5/11/2022	5th Lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.152/104/2021						226.67		
7	F.152/105/2021						226.67		
	F.152/106/2021	9/10/2022	6/11/2022	6th Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.152/107/2021						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER