

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to the nallah and Construction of Retaining wall in Sy.No. 63/2-A at Poriabhat Verna in Ward No. 2 in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.25/20/2021						164.44		No. WRD/SD I/WD II/ F.Estt/631/2021-22 DATED:- 24-12-2021
	F.25/21/2021	17-12-2021	14-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/22/2021						168.89		
2	F.25/23/2021						164.44		do
	F.25/24/2021	18-12-2021	15-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/25/2021						168.89		
3	F.25/26/2021						168.89		do
	F.25/27/2021	19-12-2021	16-01-2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.25/28/2021						164.44		
4	F.25/29/2021						164.44		do
	F.25/30/2021	20-12-2021	17-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/31/2021						168.89		
5	F.25/32/2021						168.89		do
	F.25/33/2021	21-12-2021	18-01-2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.25/34/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah and Construction of Retaining wall in Sy.No. 63/2-A at Poriebhat Verna in Ward No. 2 in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD			28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.25/35/2021						164.44		No. WRD/SD I/WD II/ F.Estt/748/2021-22 DATED:- 17-02-2022.
	F.25/36/2021	24-01-2022	21-02-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/37/2021						164.44		
1.2	F.25/38/2021						164.44		do
	F.25/39/2021	24-01-2022	21-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/40/2021						168.89		
2.1	F.25/41/2021						164.44		do
	F.25/42/2021	25-01-2022	22-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/43/2021						168.89		
2.2	F.25/44/2021						168.89		do
	F.25/45/2021	25-01-2022	22-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.25/46/2021						164.44		
3.1	F.25/47/2021						164.44		do
	F.25/48/2021	26-01-2022	23-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/49/2021						168.89		
3.2	F.25/50/2021						168.89		do
	F.25/51/2021	26-01-2022	23-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.25/52/2021						164.44		
4.1	F.25/53/2021						168.89		do
	F.25/54/2021	27-01-2022	24-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.25/55/2021						164.44		
4.2	F.25/56/2021						168.89		do
	F.25/57/2021	27-01-2022	24-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/58/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah and Construction of Retaining wall in Sy.No. 63/2-A at Porielhat Verna in Ward No. 2 in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.25/59/2021						164.44		No. WRD/SD I/WD II/ F.Estt/748/2021-22 DATED:- 17-02-2022.
	F.25/60/2021	28-01-2022	25-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/61/2021						164.44		
5.2	F.25/62/2021						164.44		do
	F.25/63/2021	28-01-2022	25-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/64/2021						168.89		
6.1	F.25/65/2021						168.89		do
	F.25/66/2021	29-01-2022	26-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/67/2021						164.44		
6.2	F.25/68/2021						164.44		do
	F.25/69/2021	29-01-2022	26-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/70/2021						164.44		
7.1	F.25/71/2021						164.44		do
	F.25/72/2021	30-01-2022	27-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/73/2021						164.44		
7.2	F.25/74/2021						164.44		do
	F.25/75/2021	30-01-2022	27-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/76/2021						168.89		
8.1	F.25/77/2021						168.89		do
	F.25/78/2021	31-01-2022	28-02-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.25/79/2021						168.89		
8.2	F.25/80/2021						168.89		do
	F.25/81/2021	31-01-2022	28-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/82/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to the nallah and Construction of Retaining wall in Sy.No. 63/2-A at Poriebhat Verna in Ward No. 2 in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.25/83/2021						164.44		No. WRD/SD I/WD II/ F.Estt/748/2021-22 DATED:- 17-02-2022.
	F.25/84/2021	1/2/2022	1/3/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.25/85/2021						164.44		
9.2	F.25/86/2021						168.89		do
	F.25/87/2021	1/2/2022	1/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/88/2021						164.44		
10.1	F.25/89/2021						164.44		do
	F.25/90/2021	2/2/2022	2/3/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/91/2021						164.44		
10.2	F.25/92/2021						164.44		do
	F.25/93/2021	2/2/2022	2/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/94/2021						168.89		
11.1	F.25/95/2022						168.89		do
	F.25/96/2022	3/2/2022	3/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/97/2023						164.44		
11.2	F.25/98/2023						164.44		do
	F.25/99/2023	3/2/2022	3/3/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/100/2024						164.44		
12.1	F.25/101/2024						164.44		do
	F.25/102/2021	4/2/2022	4/3/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.25/103/2021						164.44		
12.2	F.25/104/2021						164.44		do
	F.25/105/2021	4/2/2022	4/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.25/106/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER