

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Bandhara & Improvement to field channels & distributaries in Sy.No. 149 at Gimmona near Shri Rohidas Naik's house in ward No. 1 of V.P. in Priol Constituency in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.47/22/2021						168.89		No. WRD/WD XI/ SD IV/ W.F. 438/448/2021-22. <b>DATED: 10-01-2022</b>
	F.47/23/2021	4/1/2022	1/2/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.47/24/2021						164.44		
2	F.47/25/2021						168.89		do
	F.47/26/2021	5/1/2022	2/2/2022	For Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.47/27/2021						168.89		
3	F.47/28/2021						168.89		do
	F.47/29/2021	6/1/2022	3/2/2022	For Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.47/30/2021						164.44		
4	F.47/31/2021						164.44		do
	F.47/32/2021	7/1/2022	4/2/2022	For Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.47/33/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**