

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of nallah protection wall near the house of Yatish Suresh Naik in Village Panchayat Durbhat Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.59/23/2021						120.00		No. WRD/WD XI/ SD IV/ F.CF/432/2021-22. DATED: 06-01-2022
	F.59/24/2021	30-12-2021	27-01-2022	Nallah Foundation	1.3.6	100 kg/cm2	115.56	120.00	
	F.59/25/2021						124.44		
2	F.59/26/2021						111.11		do
	F.59/27/2021	31-12-2021	28-01-2022	Nallah Foundation	1.3.6	100 kg/cm2	120.00	118.52	
	F.59/28/2021						124.44		
3	F.59/29/2021						115.56		do
	F.59/30/2021	1/1/2022	29-01-2022	Wall Concrete	1.3.6	100 kg/cm2	124.44	120.00	
	F.59/31/2021						120.00		
4	F.59/32/2021						115.56		do
	F.59/33/2021	3/1/2022	31-01-2022	Wall Concrete	1.3.6	100 kg/cm2	124.44	118.52	
	F.59/34/2021						115.56		
5.1	F.59/35/2021						120.00		do
	F.59/36/2021	5/1/2022	2/2/2022	Wall Concrete	1.3.6	100 kg/cm2	124.44	120.00	
	F.59/37/2021						115.56		
5.2	F.59/38/2021						124.44		do
	F.59/39/2021	5/1/2022	2/2/2022	Wall Concrete	1.3.6	100 kg/cm2	120.00	118.52	
	F.59/40/2021						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of nallah protection wall near the house of Yatish Suresh Naik in Village Panchayat Durbhat Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.59/47/2021						111.11		No. WRD/WD XI/ SD IV/ F.CF/469/2021-22. DATED: 21-01-2022
	F.59/48/2021	13-01-2022	10/2/2022	Wall Concrete	1.3.6	100 kg/cm2	120.00	118.52	
	F.59/49/2021						124.44		
6.2	F.59/50/2021						115.56		do
	F.59/51/2021	13-01-2022	10/2/2022	Wall Concrete	1.3.6	100 kg/cm2	124.44	120.00	
	F.59/52/2021						120.00		
7	F.59/53/2021						115.56		do
	F.59/54/2021	15-01-2022	12/2/2022	Wall Concrete	1.3.6	100 kg/cm2	124.44	118.52	
	F.59/55/2021						115.56		
8	F.59/56/2021						120.00		do
	F.59/57/2021	18-01-2022	15-02-2022	Wall Concrete	1.3.6	100 kg/cm2	124.44	120.00	
	F.59/58/2021						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER