

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.147/04/2021						293.33		No. WRD/SD I/WD II/
	F.147/05/2021	27-09-2022	25-10-2022	Bed P.C.C	M 20	275 kg/cm ²	297.78	294.81	F.Esst/402/2022-23.
	F.147/06/2021						293.33		DATED: 01-10-2022.
2	F.147/07/2021						297.78		
	F.147/08/2021	28-09-2022	26-10-2022	Bed P.C.C	M 20	275 kg/cm ²	288.89	296.30	do
	F.147/09/2021						302.22		
3	F.147/10/2021						302.22		
	F.147/11/2021	29-09-2022	27-10-2022	Bed P.C.C	M 20	275 kg/cm ²	288.89	291.85	do
	F.147/12/2021						284.44		
4	F.147/13/2021						306.67		
	F.147/14/2021	30-09-2022	28-10-2022	Bed P.C.C	M 20	275 kg/cm ²	293.33	293.33	do
	F.147/09/2021						280.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5	F.147/10/2021						297.78		No. WRD/SD I/WD II/ F.Esst/ 423 /2022-23. DATED: 11-10-2022.
	F.147/11/2021	1/10/2022	29-10-2022	Bed P.C.C	M 20	275 kg/cm2	284.44	294.81	
	F.147/12/2021						302.22		
6	F.147/13/2021						302.22		
	F.147/14/2021	3/10/2022	31-10-2022	Bed P.C.C	M 20	275 kg/cm2	293.33	296.29	do
	F.147/15/2021						293.33		
7.1	F.147/16/2021						288.89		
	F.147/17/2021	4/10/2022	1/11/2022	Bed P.C.C	M 20	275 kg/cm2	306.67	299.26	do
	F.147/18/2021						302.22		
7.2	F.147/19/2021						302.22		
	F.147/20/2021	4/10/2022	1/11/2022	Bed P.C.C	M 20	275 kg/cm2	302.22	300.74	do
	F.147/21/2021						297.78		
8.1	F.147/22/2021						413.33		
	F.147/23/2021	8/10/2022	5/11/2022	Bed P.C.C	M 30	390 kg/cm2	422.22	417.77	do
	F.147/24/2021						417.77		
8.2	F.147/25/2021						422.22		
	F.147/26/2021	8/10/2022	5/11/2022	Bed P.C.C	M 30	390 kg/cm2	417.77	419.25	do
	F.147/27/2021						417.77		
8.3	F.147/28/2021						417.77		
	F.147/29/2021	8/10/2022	5/11/2022	Bed P.C.C	M 30	390 kg/cm2	422.22	417.77	do
	F.147/30/2021						413.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/62

. Dated:-8/12/2022

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncpal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.147/46/2021						408.88		No. WRD/SD I/WD II/ F.Esst/437/2022-23. DATED: 15-10-2022.
	F.147/47/2021	9/10/2022	6/11/2022	Raft	M 30	390 kg/cm2	404.44	405.92	
	F.147/48/2021						404.44		
9.2	F.147/49/2021						408.88		do
	F.147/50/2021	9/10/2022	6/11/2022	Raft	M 30	390 kg/cm2	404.44	408.88	
	F.147/51/2021						413.33		
9.3	F.147/52/2021						404.44		do
	F.147/53/2021	9/10/2022	6/11/2022	Raft	M 30	390 kg/cm2	417.77	407.40	
	F.147/54/2021						400.00		
9.4	F.147/55/2021						408.88		do
	F.147/56/2021	9/10/2022	6/11/2022	Raft	M 30	390 kg/cm2	404.44	408.88	
	F.147/57/2021						413.33		
10.1	F.147/58/2021						400.00		do
	F.147/59/2021	10/10/2022	7/11/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	410.37	
	F.147/60/2021						417.77		
10.2	F.147/61/2021						408.88		do
	F.147/62/2021	10/10/2022	7/11/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	410.36	
	F.147/63/2021						408.88		
10.3	F.147/64/2021						417.78		do
	F.147/65/2021	10/10/2022	7/11/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	411.85	
	F.147/66/2021						404.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	F.147/67/2021						404.44		No. WRD/SD I/WD II/ F.Esst/ 437 /2022-23. DATED: 15-10-2022.
	F.147/68/2021	11/10/2022	8/11/2022	Raft/ Wall	M 30	390 kg/cm2	395.55	400.00	
	F.147/69/2021						400.00		
11.2	F.147/70/2021						395.55		
	F.147/71/2021	11/10/2022	8/11/2022	Raft/ Wall	M 30	390 kg/cm2	400.00	398.52	do
	F.147/72/2021						400.00		
12	F.147/73/2021						413.33		
	F.147/74/2021	12/10/2022	9/11/2022	Raft/ Wall	M 30	390 kg/cm2	422.22	419.26	do
	F.147/75/2021						422.22		
13.1	F.147/76/2021						417.77		
	F.147/77/2021	13-10-2022	10/11/2022	Raft/ Wall	M 30	390 kg/cm2	426.66	419.25	do
	F.147/78/2021						413.33		
13.2	F.147/79/2021						417.77		
	F.147/80/2021	13-10-2022	10/11/2022	Raft/ Wall	M 30	390 kg/cm2	422.22	417.77	do
	F.147/81/2021						413.33		
13.3	F.147/82/2021						413.33		
	F.147/83/2021	13-10-2022	10/11/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	416.29	do
	F.147/84/2021						422.22		
14.1	F.147/85/2021						400.00		
	F.147/86/2021	14-10-2022	11/11/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	410.37	do
	F.147/87/2021						417.77		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfod- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14.2	F.147/88/2021						408.88		No. WRD/SD I/WD II/ F.Esst/437/2022-23. DATED: 15-10-2022.
	F.147/89/2021	14-10-2022	11/11/2022	Raft/ Wall	M 30	390 kg/cm2	391.11	405.92	
	F.147/90/2021						417.77		
14.3	F.147/91/2021						408.88		
	F.147/92/2021	14-10-2022	11/11/2022	Raft/ Wall	M 30	390 kg/cm2	408.88	411.84	do
	F.147/93/2021						417.77		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/ 63

. Dated:-08/12/2022

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.1	F.147/112/2021						417.77		No. WRD/SD I/WD II/ F.Esst/ 447 /2022-23. DATED: 22-10-2022.
	F.147/113/2021	15-10-2022	12/11/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	417.77	
	F.147/114/2021						422.22		
15.2	F.147/115/2021						417.77		
	F.147/116/2021	15-10-2022	12/11/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	414.81	do
	F.147/117/2021						408.88		
15.3	F.147/118/2021						413.33		
	F.147/119/2021	15-10-2022	12/11/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	416.29	do
	F.147/120/2021						417.77		
16.1	F.147/121/2021						404.44		
	F.147/122/2021	17-10-2022	14-11-2022	Raft/ Wall	M 30	390 kg/cm2	417.77	414.81	do
	F.147/123/2021						422.22		
16.2	F.147/124/2021						422.22		
	F.147/125/2021	17-10-2022	14-11-2022	Raft/ Wall	M 30	390 kg/cm2	408.88	414.81	do
	F.147/126/2021						413.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
17.1	F.147/127/2021						413.33		No. WRD/SD I/WD II/ F.Esst/447/2022-23. DATED: 22-10-2022.
	F.147/128/2021	18-10-2022	15-11-2022	Raft/ Wall	M 30	390 kg/cm ²	408.88	413.33	
	F.147/129/2021						417.77		
17.2	F.147/130/2021						422.22		do
	F.147/131/2021	18-10-2022	15-11-2022	Raft/ Wall	M 30	390 kg/cm ²	417.77	416.29	
	F.147/132/2021						408.88		
17.3	F.147/133/2021						422.22		do
	F.147/134/2021	18-10-2022	15-11-2022	Raft/ Wall	M 30	390 kg/cm ²	395.55	411.85	
	F.147/135/2021						417.77		
17.4	F.147/136/2021						413.33		do
	F.147/137/2021	18-10-2022	15-11-2022	Raft/ Wall	M 30	390 kg/cm ²	417.77	416.29	
	F.147/138/2021						417.77		
17.5	F.147/139/2021						408.88		do
	F.147/140/2021	18-10-2022	15-11-2022	Raft/ Wall	M 30	390 kg/cm ²	413.33	413.33	
	F.147/141/2021						417.77		
17.6	F.147/142/2021						417.77		do
	F.147/143/2021	18-10-2022	15-11-2022	Raft/ Wall	M 30	390 kg/cm ²	417.77	413.33	
	F.147/144/2021						404.44		
18.1	F.147/145/2021						413.33		do
	F.147/146/2021	19-10-2022	16-11-2022	Raft/ Wall	M 30	390 kg/cm ²	426.66	417.77	
	F.147/147/2021						413.33		
18.2	F.147/148/2021						422.22		do
	F.147/149/2021	19-10-2022	16-11-2022	Raft/ Wall	M 30	390 kg/cm ²	408.88	416.29	
	F.147/150/2021						417.78		

Carrie Correia
JUNIOR ENGINEER.

S.S. Velingkar
ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
18.3	F.147/151/2021						408.88		No. WRD/SD I/WD II/ F.Esst/447/2022-23. DATED: 22-10-2022.
	F.147/152/2021	19-10-2022	16-11-2022	Raft/ Wall	M 30	390 kg/cm2	417.77	413.33	
	F.147/153/2021						413.33		
19.1	F.147/154/2021						417.77		
	F.147/155/2021	20-10-2022	17-11-2022	Raft/ Wall	M 30	390 kg/cm2	422.22	417.77	do
	F.147/156/2021						413.33		
19.2	F.147/157/2021						417.77		
	F.147/158/2021	20-10-2022	17-11-2022	Raft/ Wall	M 30	390 kg/cm2	417.77	417.77	do
	F.147/159/2021						417.77		
19.3	F.147/160/2021						408.88		
	F.147/161/2021	20-10-2022	17-11-2022	Raft/ Wall	M 30	390 kg/cm2	422.22	416.29	do
	F.147/162/2021						417.77		
20.1	F.147/163/2021						284.44		
	F.147/164/2021	20-10-2022	17-11-2022	Raft/ Wall	M 20	275 kg/cm2	293.33	291.85	do
	F.147/165/2021						297.78		
20.2	F.147/166/2021						293.33		
	F.147/167/2021	20-10-2022	17-11-2022	Raft/ Wall	M 20	275 kg/cm2	297.78	296.30	do
	F.147/168/2021						297.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/65

. Dated:-09/12/2022

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfod- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
-----------	-------------	--------------	--------------	--------------------	---------------	-----------------	--------------------	------------------	-------------------

21.1	F.147/181/2021						408.88		No. WRD/SD I/WD II/
	F.147/182/2021	25-10-2022	22-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	417.77	416.29	F.Esst/464/2022-23.
	F.147/183/2021						422.22		DATED: 01-11-2022.
21.2	F.147/184/2021						413.33		
	F.147/185/2021	25-10-2022	22-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	413.33	414.81	do
	F.147/186/2021						417.77		
21.3	F.147/187/2021						413.33		
	F.147/188/2021	25-10-2022	22-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	417.77	416.29	do
	F.147/189/2021						417.77		
22.1	F.147/190/2021						408.88		
	F.147/191/2021	26-10-2022	23-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	422.22	416.29	do
	F.147/192/2021						417.77		
22.2	F.147/193/2021						417.77		
	F.147/194/2021	26-10-2022	23-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	422.22	417.77	do
	F.147/195/2021						413.33		
22.3	F.147/196/2021						422.22		
	F.147/197/2021	26-10-2022	23-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	422.22	416.29	do
	F.147/198/2021						404.44		
24.1	F.147/199/2021						417.77		
	F.147/200/2021	27-10-2022	24-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	413.33	413.33	do
	F.147/201/2021						408.88		
24.2	F.147/202/2021						417.77		
	F.147/203/2021	27-10-2022	24-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	408.88	414.81	do
	F.147/204/2021						417.77		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	F.147/205/2021						422.22		No. WRD/SD I/WD II/

24.3	F.147/206/2021	27-10-2022	24-11-2022	Wall II Lift/ Top slab	M 30	390 kg/cm2	408.88	416.29	F.Estt/ 464 /2022-23.
	F.147/207/2021						417.77		DATED: 01-11-2022.
25	F.147/208/2021						284.44		
	F.147/209/2021	27-10-2022	24-11-2022	Bed bottom	M 20	275 kg/cm2	293.33	291.85	do
	F.147/210/2021						297.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER