

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah near Shree Paikdev temple at Bondoi of Village Naqueri in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.152/06/2021						151.11		No. WRD/WD II/SD V/
	F.152/07/2021	3/10/2022	10/10/2022	Foundation	1.2.4	140 kg/cm2	155.56	154.08	F.70/151/2022-23.
	F.152/08/2021						155.56		DATED: 10-10-2022.
1.2	F.152/09/2021						155.56		
	F.152/10/2021	3/10/2022	10/10/2022	Foundation	1.2.4	140 kg/cm2	151.11	152.59	do
	F.152/11/2021						151.11		
1.3	F.152/12/2021						151.11		
	F.152/13/2021	3/10/2022	10/10/2022	Foundation	1.2.4	140 kg/cm2	155.56	151.11	do
	F.152/14/2021						146.67		
1.4	F.152/15/2021						155.56		
	F.152/16/2021	3/10/2022	10/10/2022	Foundation	1.2.4	140 kg/cm2	155.56	154.08	do
	F.152/17/2021						151.11		
1.5	F.152/18/2021						151.11		
	F.152/19/2021	3/10/2022	10/10/2022	Foundation	1.2.4	140 kg/cm2	151.11	151.11	do
	F.152/20/2021						151.11		
2.1	F.152/21/2021						155.56		
	F.152/22/2021	4/10/2022	11/10/2022	1st Lift	1.2.4	140 kg/cm2	146.67	149.63	do
	F.152/23/2021						146.67		
2.2	F.152/24/2021						146.67		
	F.152/25/2021	4/10/2022	11/10/2022	1st Lift	1.2.4	140 kg/cm2	142.22	145.19	do
	F.152/26/2021						146.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah near Shree Paikdev temple at Bondoi of Vilage Naqueri in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.3	F.152/27/2021						146.67		No. WRD/WD II/SD V/
	F.152/28/2021	4/10/2022	11/10/2022	1st Lift	1.2.4	140 kg/cm2	146.67	145.19	F.70/151/2022-23.
	F.152/29/2021						142.22		DATED: 10-10-2022.
3.1	F.152/30/2021						155.56		
	F.152/31/2021	5/10/2022	12/10/2022	2nd Lift	1.2.4	140 kg/cm2	160.00	157.04	do
	F.152/32/2021						155.56		
3.2	F.152/33/2021						155.56		
	F.152/34/2021	5/10/2022	12/10/2022	2nd Lift	1.2.4	140 kg/cm2	151.11	154.08	do
	F.152/35/2021						155.56		
3.3	F.152/36/2021						155.56		
	F.152/37/2021	5/10/2022	12/10/2022	2nd Lift	1.2.4	140 kg/cm2	155.56	157.04	do
	F.152/38/2021						160.00		
4.1	F.152/39/2021						160.00		
	F.152/40/2021	6/10/2022	13-10-2022	3rd Lift	1.2.4	140 kg/cm2	151.11	154.07	do
	F.152/41/2021						151.11		
4.2	F.152/42/2021						155.56		
	F.152/43/2021	6/10/2022	13-10-2022	3rd Lift	1.2.4	140 kg/cm2	151.11	152.59	do
	F.152/44/2021						151.11		
5.1	F.152/45/2021						146.67		
	F.152/46/2021	7/10/2022	14-10-2022	4th Lift	1.2.4	140 kg/cm2	151.11	149.63	do
	F.152/47/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah near Shree Paikdev temple at Bondoi of Vilage Naqueri in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.2	F.152/48/2021						155.56		No. WRD/WD II/SD V/
	F.152/49/2021	7/10/2022	14-10-2022	4th Lift	1.2.4	140 kg/cm2	151.11	152.59	F.70/151/2022-23.
	F.152/50/2021						151.11		DATED: 10-10-2022.
6	F.152/51/2021						164.44		
	F.152/52/2021	8/10/2022	15-10-2022	5th Lift	1.2.4	140 kg/cm2	160.00	161.48	do
	F.152/53/2021						160.00		
7	F.152/54/2021						155.56		
	F.152/55/2021	9/10/2022	16-10-2022	6th Lift	1.2.4	140 kg/cm2	155.56	157.04	do
	F.152/56/2021						160.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER