

NO.WRD/WDXI/SDIII/TECH/W.F.21/2023/2023-24/286

. Dated:-30/12/23

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent repairs to the nallah portion near Shri Sarawati Devasthan Mandir at Tisk Ponda in Ponda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F. 21/06/2023						235.56		No. WRD/WD XI/ SD IV/ F.CF/526/2023-24. DATED: 27-12-2023.
	F. 21/07/2023	1/12/2023	29-12-2023	Foundation	1.2.4	210 kg/cm ²	226.67	228.15	
	F. 21/08/2023						222.22		
1.2	F. 21/09/2023						235.56		
	F. 21/10/2023	1/12/2023	29-12-2023	Foundation	1.2.4	210 kg/cm ²	226.67	229.63	do
	F. 21/11/2023						226.67		
2	F. 21/12/2023						231.11		
	F. 21/13/2023	2/12/2023	30-12-2023	Lining	1.2.4	210 kg/cm ²	222.22	225.18	do
	F. 21/14/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER