

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting and Improvement of existing drain at Azadnagar Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.21/10/2021						173.33		No.289/SD III/WDIII/ WRD/2021-22/359. DATED: 07-12-2021.
	F.21/11/2021	4/12/2021	1/1/2022	Foundation of drain	1.2.4	150 kg/cm ²	182.22	177.78	
	F.21/12/2021						177.78		
2	F.21/13/2021						164.44		
	F.21/14/2021	7/12/2021	4/1/2022	Side walls of the drain	1.2.4	150 kg/cm ²	186.67	180.74	do
	F.21/15/2021						191.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER