

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of slab culvert for roads access at ch.1.500Kms of Branch canal of SIP to the fields under survey no. 36,37 and 48 of Talverdam villages of Salcete Taluka

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1.1	F.7/40/2021						168.89		No.WRD/SD III/ WD
	F.7/41/2021	25/11/2021	23-12-2021	Foundation of culvert	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	XIV/W.F-5/2021-22/183
	F.7/42/2021						168.89		<b>DATED: 30-11-2021.</b>
1.2	F.7/43/2021						164.44		
	F.7/44/2021	25/11/2021	23-12-2021	Foundation of culvert	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	do
	F.7/45/2021						168.89		
2.1	F.7/46/2021						164.44		
	F.7/47/2021	29/11/2021	27-12-2021	Abutment wall of culvert	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	do
	F.7/48/2021						168.89		
2.2	F.7/49/2021						168.89		
	F.7/50/2021	29/11/2021	27-12-2021	Abutment wall of culvert	1.2.4	150 kg/cm <sup>2</sup>	164.44	167.41	do
	F.7/51/2021						168.89		
3	F.7/52/2021						168.89		
	F.7/53/2021	30/11/2021	28-12-2021	Abutment wall of culvert	1.2.4	150 kg/cm <sup>2</sup>	164.44	167.41	do
	F.7/54/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of slab culvert for roads access at ch.1.500Kms of Branch canal of SIP to the fields under survey no. 36,37 and 48 of Talverdam villages of Salcete Taluka

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	F.7/55/2021						231.11		No.WRD/SD III/ WD
	F.7/56/2021	10/12/2021	7/1/2022	slab culvert	1. 1 1/2. 3	200 kg/cm <sup>2</sup>	231.11	231.11	XIV/W.F-5/2021-22/185
	F.7/57/2021						231.11		<b>DATED: 13-12-2021.</b>
2	F.7/58/2021						240.00		
	F.7/59/2021	10/12/2021	7/1/2022	slab culvert	1. 1 1/2. 3	200 kg/cm <sup>2</sup>	231.11	235.56	do
	F.7/60/2021						235.56		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**