

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of bridge across branch canal of SIP at Ghonger in ward IV of Cuncolim Muncipal area of Cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.8/29/2021						168.89		No.WRD/SD III/ WD XIV/W.F-5/2021-22/181 DATED: 29-11-2021.
	F.8/30/2021	24/11/2021	22-12-2021	Foundation of culvert	1.2.4	150 kg/cm2	168.89	168.89	
	F.8/31/2021						168.89		
1.2	F.8/32/2021						164.44		do
	F.8/33/2021	24/11/2021	22-12-2021	Foundation of culvert	1.2.4	150 kg/cm2	164.44	165.92	
	F.8/34/2021						168.89		
2.1	F.8/35/2021						164.44		do
	F.8/36/2021	26-11-2021	24-12-2021	Foundation of culvert	1.2.4	150 kg/cm2	168.89	167.41	
	F.8/37/2021						168.89		
2.2	F.8/38/2021						168.89		do
	F.8/39/2021	26-11-2021	24-12-2021	Foundation of culvert	1.2.4	150 kg/cm2	164.44	167.41	
	F.8/40/2021						168.89		
3.1	F.8/41/2021						168.89		do
	F.8/42/2021	27-11-2021	25-12-2021	Foundation of culvert	1.2.4	150 kg/cm2	164.44	167.41	
	F.8/43/2021						168.89		
3.2	F.8/44/2021						168.89		do
	F.8/45/2021	27-11-2021	25-12-2021	Foundation of culvert	1.2.4	100 kg/cm2	168.89	168.89	
	F.8/46/2021						168.89		
4.1	F.8/47/2021						231.11		No.WRD/SD III/ WD XIV/W.F-5/2021-22/186 DATED: 13-12-2021.
	F.8/48/2021	9/12/2021	6/1/2022	Slab Culvert	1.1.5.3	200 kg/cm2	231.11	231.11	
	F.8/49/2021						231.11		
4.2	F.8/50/2021						240.00		do
	F.8/51/2021	9/12/2021	6/1/2022	Slab Culvert	1.1.5.3	200 kg/cm2	231.11	235.56	
	F.8/52/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER