

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.36/42/2021						217.78		No. WRD/WD XII/SD V/ F.36/137/2021-22 DATED:- 23-12-2021
	F.36/43/2021	15-12-2021	12/1/2022	LHS Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/44/2021						222.22		
1.2	F.36/45/2021						222.22		do
	F.36/46/2021	15-12-2021	12/1/2022	LHS Foundation	1.2.4	210 kg/cm2	222.22	222.22	
	F.36/47/2021						222.22		
1.3	F.36/48/2021						217.78		do
	F.36/49/2021	15-12-2021	12/1/2022	LHS Foundation	1.2.4	210 kg/cm2	217.78	214.82	
	F.36/50/2021						208.89		
1.4	F.36/51/2021						213.33		do
	F.36/52/2021	15-12-2021	12/1/2022	LHS Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.36/53/2021						222.22		
2.1	F.36/54/2021						213.33		do
	F.36/55/2021	16-12-2021	13-01-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/56/2021						217.78		
2.2	F.36/57/2021						217.78		do
	F.36/58/2021	16-12-2021	13-01-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/59/2021						213.33		
3.1	F.36/60/2021						217.78		do
	F.36/61/2021	17-12-2021	14-01-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	216.30	
	F.36/62/2021			LHS 1st Lift			217.78		
3.2	F.36/63/2021						213.33		do
	F.36/64/2021	17-12-2021	14-01-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/65/2021			LHS 1st Lift			217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.36/66/2021						213.33		No. WRD/WD XII/SD V/ F.36/137/2021-22 DATED:- 23-12-2021
	F.36/67/2021	18-12-2021	15-01-2022	LHS 1st Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/68/2021						217.78		
4.2	F.36/69/2021						217.78		do
	F.36/70/2021	18-12-2021	15-01-2022	LHS 1st Lift	1.2.4	210 kg/cm2	217.78	217.78	
	F.36/71/2021						217.78		
5.1	F.36/72/2021						217.78		do
	F.36/73/2021	20-12-2021	17-01-2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/74/2021						217.78		
5.2	F.36/75/2021						217.78		do
	F.36/76/2021	20-12-2021	17-01-2022	LHS 1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/77/2021						213.33		
6.1	F.36/78/2021						217.78		do
	F.36/79/2021	21-12-2021	18-01-2022	LHS 1st Lift & LHS 2nd Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/80/2021						217.78		
6.2	F.36/81/2021						222.22		do
	F.36/82/2021	21-12-2021	18-01-2022	LHS 1st Lift & LHS 2nd Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/83/2021						217.78		
7.1	F.36/84/2021						213.33		do
	F.36/85/2021	22-12-2021	19-01-2022	LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/86/2021						213.33		
7.2	F.36/87/2021						213.33		do
	F.36/88/2021	22-12-2021	19-01-2022	LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	211.85	
	F.36/89/2021						208.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.1	F.36/117/2021						213.33		No. WRD/WD XII/SD V/
	F.36/118/2021	23-12-2021	20-01-2022	LHS 3rd Lift & RHS Foundation	1.2.4	210 kg/cm2	213.33	213.33	F.36/145/2021-22
	F.36/119/2021						213.33		DATED:- 01-01-2022
8.2	F.36/120/2021						213.33		
	F.36/121/2021	23-12-2021	20-01-2022	LHS 3rd Lift & RHS Foundation	1.2.4	210 kg/cm2	222.22	216.29	do
	F.36/122/2021						213.33		
8.3	F.36/123/2021						213.33		
	F.36/124/2021	23-12-2021	20-01-2022	LHS 3rd Lift & RHS Foundation	1.2.4	210 kg/cm2	217.78	216.30	do
	F.36/125/2021						217.78		
8.4	F.36/126/2021						208.89		
	F.36/127/2021	23-12-2021	20-01-2022	LHS 3rd Lift & RHS Foundation	1.2.4	210 kg/cm2	217.78	213.33	do
	F.36/128/2021						213.33		
9.1	F.36/129/2021						217.78		
	F.36/130/2021	24-12-2021	21-01-2022	RHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	do
	F.36/131/2021						213.33		
9.2	F.36/132/2021						213.33		
	F.36/133/2021	24-12-2021	21-01-2022	RHS Foundation	1.2.4	210 kg/cm2	217.78	216.30	do
	F.36/134/2021						217.78		
9.3	F.36/135/2021						213.33		
	F.36/136/2021	24-12-2021	21-01-2022	RHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	do
	F.36/137/2021						217.78		
9.4	F.36/138/2021						217.78		
	F.36/139/2021	24-12-2021	21-01-2022	RHS Foundation	1.2.4	210 kg/cm2	217.78	214.82	do
	F.36/140/2021						208.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10.1	F.36/141/2021						213.33		No. WRD/WD XII/SD V/
	F.36/142/2021	26-12-2021	23-01-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	214.81	F.36/145/2021-22
	F.36/143/2021						217.78		DATED:- 01-01-2022
10.2	F.36/144/2021						217.78		
	F.36/145/2021	26-12-2021	23-01-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	217.78	do
	F.36/146/2021						222.22		
10.3	F.36/147/2021						208.89		
	F.36/148/2021	26-12-2021	23-01-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	213.33	do
	F.36/149/2021						217.78		
10.4	F.36/150/2021						213.33		
	F.36/151/2021	26-12-2021	23-01-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	217.78	do
	F.36/152/2021						226.67		
11.1	F.36/153/2021						217.78		
	F.36/154/2021	27-12-2021	24-01-2022	RHS 1st Lift	1.2.4	210 kg/cm2	217.78	217.78	do
	F.36/155/2021						217.78		
11.2	F.36/156/2021						213.33		
	F.36/157/2021	27-12-2021	24-01-2022	RHS 1st Lift	1.2.4	210 kg/cm2	217.78	216.30	do
	F.36/158/2021						217.78		
12.1	F.36/159/2021						217.78		
	F.36/160/2021	28-12-2021	25-01-2022	RHS 2nd Lift	1.2.4	210 kg/cm2	213.33	217.78	do
	F.36/161/2021						222.22		
12.2	F.36/162/2021						217.78		
	F.36/163/2021	28-12-2021	25-01-2022	RHS 2nd Lift	1.2.4	210 kg/cm2	217.78	217.78	do
	F.36/164/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
12.3	F.36/165/2021						217.78		No. WRD/WD XII/SD V/
	F.36/166/2021	28-12-2021	25-01-2022	RHS 2nd Lift	1.2.4	210 kg/cm ²	217.78	217.78	F.36/145/2021-22
	F.36/167/2021						217.78		DATED:- 01-01-2022
12.4	F.36/168/2021						217.78		
	F.36/169/2021	28-12-2021	25-01-2022	RHS 2nd Lift	1.2.4	210 kg/cm ²	213.33	217.78	do
	F.36/170/2021						222.22		
13.1	F.36/171/2021						217.78		
	F.36/172/2021	29-12-2021	26-01-2022	RHS 3rd Lift	1.2.4	210 kg/cm ²	222.22	220.74	do
	F.36/173/2021						222.22		
13.2	F.36/174/2021						217.78		
	F.36/175/2021	29-12-2021	26-01-2022	RHS 3rd Lift	1.2.4	210 kg/cm ²	217.78	219.26	do
	F.36/176/2021						222.22		
14	F.36/177/2021						217.78		
	F.36/178/2021	30-12-2021	27-01-2022	RHS 4th Lift	1.2.4	210 kg/cm ²	222.22	220.74	do
	F.36/179/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	F.36/240/2021						208.89		No. WRD/WD XII/SD V/ F.36/164/2021-22 DATED:- 25-01-2022
	F.36/241/2021	18-01-2022	15-02-2022	RHS Foundation	1.2.4	210 kg/cm2	213.33	211.85	
	F.36/242/2021						213.33		
11.2	F.36/243/2021						213.33		do
	F.36/244/2021	18-01-2022	15-02-2022	RHS Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/245/2021						213.33		
11.3	F.36/246/2021						213.33		do
	F.36/247/2021	18-01-2022	15-02-2022	RHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/248/2021						217.78		
11.4	F.36/249/2021						213.33		do
	F.36/250/2021	18-01-2022	15-02-2022	RHS Foundation	1.2.4	210 kg/cm2	226.67	217.78	
	F.36/251/2021						213.33		
12.1	F.36/252/2021						213.33		do
	F.36/253/2021	19-01-2022	16-02-2022	RHS Foundation & LHS Foundation	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/254/2021						222.22		
12.2	F.36/255/2021						213.33		do
	F.36/256/2021	19-01-2022	16-02-2022	RHS Foundation & LHS Foundation	1.2.4	210 kg/cm2	213.33	217.78	
	F.36/257/2021						226.67		
13.1	F.36/258/2021						213.33		do
	F.36/259/2021	20-01-2022	17-02-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	216.29	
	F.36/260/2021						222.22		
13.2	F.36/261/2021						226.67		do
	F.36/262/2021	20-01-2022	17-02-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	216.30	
	F.36/263/2021						208.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.3	F.36/264/2021						213.33		No. WRD/WD XII/SD V/ F.36/164/2021-22 DATED:- 25-01-2022
	F.36/265/2021	20-01-2022	17-02-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/266/2021						213.33		
13.4	F.36/267/2021						217.78		do
	F.36/268/2021	20-01-2022	17-02-2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	216.30	
	F.36/269/2021						217.78		
14.1	F.36/270/2021						217.78		do
	F.36/271/2021	21-01-2022	18-02-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	210 kg/cm2	217.78	219.26	
	F.36/272/2021						222.22		
14.2	F.36/273/2021						222.22		do
	F.36/274/2021	21-01-2022	18-02-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	210 kg/cm2	217.78	220.74	
	F.36/275/2021						222.22		
14.3	F.36/276/2021						213.33		do
	F.36/277/2021	21-01-2022	18-02-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	210 kg/cm2	208.89	213.33	
	F.36/278/2021						217.78		
14.4	F.36/279/2021						213.33		do
	F.36/280/2021	21-01-2022	18-02-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/281/2021						217.78		
15.1	F.36/282/2021						217.78		do
	F.36/283/2021	22-01-2022	19-02-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	216.30	
	F.36/284/2021						217.78		
15.2	F.36/285/2021						217.78		do
	F.36/286/2021	22-01-2022	19-02-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	210 kg/cm2	217.78	217.78	
	F.36/287/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.3	F.36/288/2021						213.33		No. WRD/WD XII/SD V/ F.36/164/2021-22 DATED:- 25-01-2022
	F.36/289/2021	22-01-2022	19-02-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/290/2021						213.33		
15.4	F.36/291/2021						213.33		do
	F.36/292/2021	22-01-2022	19-02-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	210 kg/cm2	217.78	214.81	
	F.36/293/2021						213.33		
16.1	F.36/294/2021						213.33		do
	F.36/295/2021	24-01-2022	21-02-2022	RHS 3rd Lift & LHS 3rd Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/296/2021						217.78		
16.2	F.36/297/2021						208.89		do
	F.36/298/2021	24-01-2022	21-02-2022	RHS 3rd Lift & LHS 3rd Lift	1.2.4	210 kg/cm2	217.78	213.33	
	F.36/299/2021						213.33		
17.1	F.36/300/2021						217.78		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/301/2021	29-01-2022	26-02-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/302/2021						213.33		
17.2	F.36/303/2021						213.33		do
	F.36/304/2021	29-01-2022	26-02-2022	LHS Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/305/2021						226.67		
17.3	F.36/306/2021						213.33		do
	F.36/307/2021	29-01-2022	26-02-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/308/2021						217.78		
17.4	F.36/309/2021						217.78		do
	F.36/310/2021	29-01-2022	26-02-2022	LHS Foundation	1.2.4	210 kg/cm2	217.78	214.82	
	F.36/311/2021						208.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
18.1	F.36/312/2021						213.33		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/313/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/314/2021						217.78		
18.2	F.36/315/2021						217.78		do
	F.36/316/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.36/317/2021						217.78		
18.3	F.36/318/2021						217.78		do
	F.36/319/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/320/2021						217.78		
18.4	F.36/321/2021						217.78		do
	F.36/322/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/323/2021						213.33		
18.5	F.36/324/2021						217.78		do
	F.36/325/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/326/2021						217.78		
18.6	F.36/327/2021						222.22		do
	F.36/328/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/329/2021						217.78		
18.7	F.36/330/2021						213.33		do
	F.36/331/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/332/2021						213.33		
18.8	F.36/333/2021						213.33		do
	F.36/334/2021	30-01-2022	27-02-2022	LHS Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/335/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.1	F.36/336/2021						222.22		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/337/2021	1/2/2022	1/3/2022	LHS Foundation & RHS Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/338/2021						217.78		
19.2	F.36/339/2021						217.78		do
	F.36/340/2021	1/2/2022	1/3/2022	LHS Foundation & RHS Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/341/2021						213.33		
19.3	F.36/342/2021						217.78		do
	F.36/343/2021	1/2/2022	1/3/2022	LHS Foundation & RHS Foundation	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/344/2021						217.78		
19.4	F.36/345/2021						222.22		do
	F.36/346/2021	1/2/2022	1/3/2022	LHS Foundation & RHS Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/347/2021						217.78		
20.1	F.36/348/2021						217.78		do
	F.36/349/2021	2/2/2022	2/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/350/2021						217.78		
20.2	F.36/351/2021						222.22		do
	F.36/352/2021	2/2/2022	2/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/353/2021						217.78		
20.3	F.36/354/2021						217.78		do
	F.36/355/2021	2/2/2022	2/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/356/2021						213.33		
20.4	F.36/357/2021						217.78		do
	F.36/358/2021	2/2/2022	2/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/359/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
20.5	F.36/360/2021						217.78		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/361/2021	2/2/2022	2/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/362/2021						217.78		
20.6	F.36/363/2021						222.22		do
	F.36/364/2021	2/2/2022	2/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/365/2021						217.78		
21.1	F.36/366/2021						213.33		do
	F.36/367/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/368/2021						213.33		
21.2	F.36/369/2021						213.33		do
	F.36/370/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	213.33	217.78	
	F.36/371/2021						226.67		
21.3	F.36/372/2021						222.22		do
	F.36/373/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/374/2021						217.78		
21.4	F.36/375/2021						217.78		do
	F.36/376/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/377/2021						213.33		
21.5	F.36/378/2021						217.78		do
	F.36/379/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/380/2021						217.78		
21.6	F.36/381/2021						222.22		do
	F.36/382/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/383/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
21.7	F.36/384/2021						213.33		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/385/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/386/2021						217.78		
21.8	F.36/387/2021						217.78		do
	F.36/388/2021	3/2/2022	3/3/2022	LHS 1st Lift	1.2.4	210 kg/cm2	217.78	217.78	
	F.36/389/2021						217.78		
22.1	F.36/390/2021						217.78		do
	F.36/391/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/392/2021						217.78		
22.2	F.36/393/2021						217.78		do
	F.36/394/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/395/2021						213.33		
22.3	F.36/396/2021						217.78		do
	F.36/397/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/398/2021						217.78		
22.4	F.36/399/2021						222.22		do
	F.36/400/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/401/2021						217.78		
22.5	F.36/402/2021						213.33		do
	F.36/403/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/404/2021						213.33		
22.6	F.36/405/2021						213.33		do
	F.36/406/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	216.29	
	F.36/407/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
22.7	F.36/408/2021						213.33		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/409/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/410/2021						213.33		
22.8	F.36/411/2021						213.33		do
	F.36/412/2021	4/2/2022	4/3/2022	LHS 2nd Lift	1.2.4	210 kg/cm2	217.78	214.81	
	F.36/413/2021						213.33		
23.1	F.36/414/2021						213.33		do
	F.36/415/2021	5/2/2022	5/3/2022	LHS 3rd Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/416/2021						217.78		
23.2	F.36/417/2021						208.89		do
	F.36/418/2021	5/2/2022	5/3/2022	LHS 3rd Lift	1.2.4	210 kg/cm2	217.78	213.33	
	F.36/419/2021						213.33		
23.3	F.36/420/2021						217.78		do
	F.36/421/2021	5/2/2022	5/3/2022	LHS 3rd Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/422/2021						213.33		
23.4	F.36/423/2021						213.33		do
	F.36/424/2021	5/2/2022	5/3/2022	LHS 3rd Lift	1.2.4	210 kg/cm2	213.33	216.29	
	F.36/425/2021						222.22		
24.1	F.36/426/2021						213.33		do
	F.36/427/2021	7/2/2022	7/3/2022	LHS 4th Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/428/2021						217.78		
24.2	F.36/429/2021						217.78		do
	F.36/430/2021	7/2/2022	7/3/2022	LHS 4th Lift	1.2.4	210 kg/cm2	217.78	214.82	
	F.36/431/2021						208.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
25.1	F.36/432/2021						217.78		No. WRD/WD XII/SD V/ F.36/178/2021-22 DATED:- 15-02-2022
	F.36/433/2021	8/2/2022	8/3/2022	RHS 1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.36/434/2021						213.33		
25.2	F.36/435/2021						217.78		do
	F.36/436/2021	8/2/2022	8/3/2022	RHS 1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.36/437/2021						217.78		
26.1	F.36/438/2021						222.22		do
	F.36/439/2021	10/2/2022	10/3/2022	RHS 2nd Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/440/2021						217.78		
26.2	F.36/441/2021						213.33		do
	F.36/442/2021	10/2/2022	10/3/2022	RHS 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	
	F.36/443/2021						213.33		
27.1	F.36/444/2021						213.33		do
	F.36/445/2021	11/2/2022	11/3/2022	RHS 1st Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.36/446/2021			RHS 1st Lift			217.78		
27.2	F.36/447/2021						222.22		do
	F.36/448/2021	11/2/2022	11/3/2022	RHS 1st Lift	1.2.4	210 kg/cm2	222.22	220.74	
	F.36/449/2021			RHS 1st Lift			217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER