

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.61/149/2021						164.44		No. WRD/SD III/WD XIV/ W.F.10/2021-22/209 DATED:- 11-01-2022.
	F.61/150/2021	7/1/2022	4/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/151/2021			foundation right side			164.44		
1.2	F.61/152/2021						164.44		do
	F.61/153/2021	7/1/2022	4/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/154/2021			foundation right side			168.89		
2.1	F.61/155/2021						164.44		do
	F.61/156/2021	7/1/2022	4/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/157/2021			foundation left side			168.89		
2.2	F.61/158/2021						168.89		do
	F.61/159/2021	7/1/2022	4/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.61/160/2021			foundation left side			164.44		
3.1	F.61/161/2021						164.44		do
	F.61/162/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/163/2021			foundation right side			168.89		
3.2	F.61/164/2021						168.89		do
	F.61/165/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.61/166/2021			foundation right side			164.44		
3.3	F.61/167/2021						168.89		do
	F.61/168/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.61/169/2021			foundation right side			164.44		
3.4	F.61/170/2021						168.89		do
	F.61/171/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/172/2021			foundation right side			164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.61/173/2021						164.44		No. WRD/SD III/WD XIV/ W.F.10/2021-22/209 DATED:- 11-01-2022.
	F.61/174/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/175/2021			foundation left side			164.44		
4.2	F.61/176/2021						164.44		do
	F.61/177/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/178/2021			foundation left side			168.89		
4.3	F.61/179/2021						168.89		do
	F.61/180/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/181/2021			foundation left side			164.44		
4.4	F.61/182/2021						164.44		do
	F.61/183/2021	8/1/2022	5/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/184/2021			foundation left side			164.44		
5.1	F.61/185/2021						164.44		No. WRD/SD III/WD XIV/ W.F.10/2021-22/212 DATED:- 14-01-2022.
	F.61/186/2021	10/1/2022	7/2/2022	Right side Abutment wall of slab culvert	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/187/2021						164.44		
5.2	F.61/188/2021						164.44		do
	F.61/189/2021	10/1/2022	7/2/2022	Right side Abutment wall of slab culvert	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/190/2021						168.89		
5.3	F.61/191/2021						168.89		do
	F.61/192/2021	10/1/2022	7/2/2022	Right side Abutment wall of slab culvert	1.2.4	150 kg/cm2	164.44	167.41	
	F.61/193/2021						168.89		
5.4	F.61/194/2021						168.89		do
	F.61/195/2021	10/1/2022	7/2/2022	Right side Abutment wall of slab culvert	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/196/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.61/197/2021						164.44		No. WRD/SD III/WD XIV/ W.F.10/2021-22/212 DATED:- 14-01-2022.
	F.61/198/2021	10/1/2022	7/2/2022	Left side Abutment wall of slab culvert	1.2.4	150 kg/cm2	164.44	164.44	
	F.61/199/2021						164.44		
6.2	F.61/200/2021						168.89		do
	F.61/201/2021	10/1/2022	7/2/2022	Left side Abutment wall of slab culvert	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/202/2021						164.44		
6.3	F.61/203/2021						164.44		do
	F.61/204/2021	10/1/2022	7/2/2022	Left side Abutment wall of slab culvert	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/205/2021						164.44		
6.4	F.61/206/2021						164.44		do
	F.61/207/2021	10/1/2022	7/2/2022	Left side Abutment wall of slab culvert	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/208/2021						168.89		
7.1	F.61/209/2021						168.89		No. WRD/SD III/WD XIV/ W.F.10/2021-22/214 DATED:- 16-01-2022.
	F.61/210/2021	11/1/2022	8/2/2022	RCC slab culvert abutment wall right side	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/211/2021						164.44		
7.2	F.61/212/2021						164.44		do
	F.61/213/2021	11/1/2022	8/2/2022	RCC slab culvert abutment wall right side	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/214/2021						164.44		
7.3	F.61/215/2021						164.44		do
	F.61/216/2021	11/1/2022	8/2/2022	RCC slab culvert abutment wall right side	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/217/2021						164.44		
8.1	F.61/218/2021						164.44		do
	F.61/219/2021	11/1/2022	8/2/2022	RCC slab culvert abutment wall left side	1.2.4	150 kg/cm2	164.44	165.92	
	F.61/220/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.2	F.61/221/2021						164.44		No. WRD/SD III/WD XIV/ W.F.10/2021-22/214 DATED:- 16-01-2022.
	F.61/222/2021	11/1/2022	8/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.61/223/2021			left side			164.44		
8.3	F.61/224/2021						164.44		
	F.61/225/2021	11/1/2022	8/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.61/226/2021			left side			168.89		
9.1	F.61/227/2021						168.89		
	F.61/228/2021	12/1/2022	9/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.61/229/2021			right side			164.44		
9.2	F.61/230/2021						164.44		
	F.61/231/2021	12/1/2022	9/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.61/232/2021			right side			164.44		
9.3	F.61/233/2021						164.44		
	F.61/234/2021	12/1/2022	9/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.61/235/2021			right side			164.44		
10.1	F.61/236/2021						164.44		
	F.61/237/2021	12/1/2022	9/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.61/238/2021			left side			168.89		
10.2	F.61/239/2021						168.89		
	F.61/240/2021	12/1/2022	9/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	167.41	do
	F.61/241/2021			left side			168.89		
10.3	F.61/242/2021						168.89		
	F.61/243/2021	12/1/2022	9/2/2022	RCC slab culvert abutment wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.61/244/2021			left side			164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	F.61/245/2021						240.00		No. WRD/SD III/WD XIV/
	F.61/246/2021	11/5/2022	8/6/2022	RCC slab	1.1.5.3	200 kg/cm2	231.11	235.56	W.F.10/2022-23/41
	F.61/247/2021						235.56		DATED:- 16-05-2022.
11.2	F.61/248/2021						235.56		
	F.61/249/2021	11/5/2022	8/6/2022	RCC slab	1.1.5.3	200 kg/cm2	235.56	237.04	do
	F.61/250/2021						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER