

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to tank (Spring) at Madlem V.P. Wadi Talaulim in Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.80/29/2021						164.44		No. WRD/WD XI/SD IV/ W.F.432/506/2021-22 DATED:- 07-03-2022
	F.80/30/2021	2/3/2022	30-03-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.80/31/2021						164.44		
2	F.80/32/2021						164.44		do
	F.80/33/2021	3/3/2022	31-03-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.80/34/2021						168.89		
3	F.80/35/2021						168.89		do
	F.80/36/2021	4/3/2022	1/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.80/37/2021						164.44		
4	F.80/38/2021						164.44		do
	F.80/39/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.80/40/2021						164.44		
5	F.80/41/2021						164.44		No. WRD/WD XI/SD IV/ W.F.432/517/2021-22 DATED:- 15-03-2022
	F.80/42/2021	8/3/2022	5/4/2022	Above Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.80/43/2021						164.44		
6	F.80/44/2021						164.44		do
	F.80/45/2021	9/3/2022	6/4/2022	Above Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.80/40/2021						168.89		
7	F.80/41/2021						168.89		do
	F.80/42/2021	10/3/2022	7/4/2022	Above Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.80/43/2021						168.89		
8	F.80/44/2021						164.44		do
	F.80/45/2021	11/3/2022	8/4/2022	Above Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.80/46/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER