

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall to the land bearing Chalta No. 221 of P.T. Sheet No. 3 of Margao City at Aquem, Margao.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1805						164.44		No. W.F. 260/SDIII /WD III WRD/ 2020-21/367. DATED: 09-02-2021.
	1806	4/2/2021	4/3/2021	In Foundation	1.2.4	150 kg/cm2	160.00	161.48	
	1807						160.00		
2	1808						160.00		do
	1809	4/2/2021	4/3/2021	In Foundation	1.2.4	150 kg/cm2	160.00	160.00	
	1810						160.00		
3	1811						160.00		do
	1812	6/2/2021	6/3/2021	In 1st Lift 0.00 m to 28.00 mts	1.2.4	150 kg/cm2	164.44	162.96	
	1813						164.44		
4	1814						164.44		do
	1815	6/2/2021	6/3/2021	In 1st Lift 0.00 m to 28.00 mts	1.2.4	150 kg/cm2	160.00	161.48	
	1816						160.00		
5	1817						164.44		do
	1818	8/2/2021	8/3/2021	In 2nd Lift 0.00 to 28.00 mts	1.2.4	150 kg/cm2	160.00	162.96	
	1819						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER