

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent repairs to the existing bandhara situated at Condi of Quepem Taluka in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.85/18/2021						164.44		No. WRD/WD XII/ SD V/ F.15/177/2021-22 DATED:-15-02-2022
	F.85/19/2021	9/2/2022	9/3/2022	In front of wall & Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.85/20/2021						168.89		
1.2	F.85/21/2021						164.44		
	F.85/22/2021	9/2/2022	9/3/2022	In front of wall & Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.85/23/2021						168.89		
2	F.85/24/2021						168.89		
	F.85/25/2021	10/2/2022	10/3/2022	Back & Infront of Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.85/26/2021						164.44		
3	F.85/27/2021						164.44		
	F.85/28/2021	11/2/2022	11/3/2022	Side wall & back Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.85/29/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER