

NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/59

Dated:-07/12/2022

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
26.1	F.147/226/2021						404.44		No. WRD/SD I/WD II/ F.Esst/484/2022-23. <b>DATED: 11-11-2022.</b>
	F.147/227/2021	3/11/2022	1/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	413.33	
	F.147/228/2021						417.77		
26.2	F.147/229/2021						413.33		do
	F.147/230/2021	3/11/2022	1/12/2022	Raft/ Wall	M 30	390 kg/cm2	408.88	413.33	
	F.147/231/2021						417.77		
26.3	F.147/232/2021						408.88		do
	F.147/233/2021	3/11/2022	1/12/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	410.36	
	F.147/234/2021						408.88		
26.4	F.147/235/2021						417.77		do
	F.147/236/2021	3/11/2022	1/12/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	413.33	
	F.147/237/2021						408.88		
27.1	F.147/238/2021						413.33		do
	F.147/239/2021	4/11/2022	2/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	414.81	
	F.147/240/2021						413.33		
27.2	F.147/241/2021						422.22		do
	F.147/242/2021	4/11/2022	2/12/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	414.81	
	F.147/243/2021						408.88		
28.1	F.147/244/2021						417.77		do
	F.147/245/2021	5/11/2022	5/12/2022	Raft/ Wall	M 30	390 kg/cm2	422.22	416.29	
	F.147/246/2021						408.88		
28.2	F.147/247/2021						417.77		do
	F.147/248/2021	5/11/2022	5/12/2022	Raft/ Wall	M30	390 kg/cm2	391.11	410.37	
	F.147/249/2021						422.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
28.3	F.147/250/2021						417.77		No. WRD/SD I/WD II/ F.Esst/484/2022-23. <b>DATED: 11-11-2022.</b>
	F.147/251/2021	5/11/2022	5/12/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	414.81	
	F.147/252/2021						413.33		
29.1	F.147/253/2021						422.22		
	F.147/254/2021	7/11/2022	5/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	422.22	do
	F.147/255/2021						426.66		
29.2	F.147/256/2021						417.77		
	F.147/257/2021	7/11/2022	5/12/2022	Raft/ Wall	M 30	390 kg/cm2	422.22	419.25	do
	F.147/258/2021						417.77		
30.1	F.147/259/2021						417.77		
	F.147/260/2021	8/11/2022	6/12/2022	Raft/ Wall	M 30	390 kg/cm2	408.88	410.36	do
	F.147/261/2021						404.44		
30.2	F.147/262/2021						408.88		
	F.147/263/2021	8/11/2022	6/12/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	410.36	do
	F.147/264/2021						408.88		
31.1	F.147/265/2021						417.77		
	F.147/266/2021	9/11/2022	7/12/2022	Raft/ Wall	M 30	390 kg/cm2	400.00	411.85	do
	F.147/267/2021						417.77		
31.2	F.147/268/2021						413.33		
	F.147/269/2021	9/11/2022	7/12/2022	Raft/ Wall	M 30	390 kg/cm2	404.44	408.88	do
	F.147/270/2021						408.88		
31.3	F.147/271/2021						293.33		
	F.147/272/2021	9/11/2022	7/12/2022	Raft/ Wall	M 20	275 kg/cm2	288.89	288.89	do
	F.147/273/2021						284.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/75**

**. Dated:-17/12/2022**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
32.1	F.147/299/2021						408.88		No. WRD/SD I/WD II/ F.Esst/496/2022-23. <b>DATED: 18-11-2022.</b>
	F.147/300/2021	10/11/2022	8/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	408.88	
	F.147/301/2021						400.00		
32.2	F.147/302/2021						413.33		do
	F.147/303/2021	10/11/2022	8/12/2022	Raft/ Wall	M30	390 kg/cm2	417.77	413.33	
	F.147/304/2021						408.88		
32.3	F.147/305/2021						404.44		do
	F.147/306/2021	10/11/2022	8/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	411.85	
	F.147/307/2021						413.33		
33.1	F.147/308/2021						413.33		do
	F.147/309/2021	11/11/2022	9/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	414.81	
	F.147/310/2021						413.33		
33.2	F.147/311/2021						422.22		do
	F.147/312/2021	11/11/2022	9/12/2022	Raft/ Wall	M 30	390 kg/cm2	408.88	414.81	
	F.147/313/2021						413.33		
33.3	F.147/314/2021						417.77		do
	F.147/315/2021	11/11/2022	9/12/2022	Raft/ Wall	M 30	390 kg/cm2	404.44	411.85	
	F.147/316/2021						413.33		
34.1	F.147/317/2021						408.88		do
	F.147/318/2021	12/11/2022	10/12/2022	Raft/ Wall	M 30	390 kg/cm2	391.11	405.92	
	F.147/319/2021						417.77		
34.2	F.147/320/2021						413.33		do
	F.147/321/2021	12/11/2022	10/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	416.29	
	F.147/322/2021						417.77		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
34.3	F.147/323/2021						417.77		No. WRD/SD I/WD II/ F.Esst/496/2022-23. <b>DATED: 18-11-2022.</b>
	F.147/324/2021	12/11/2022	10/12/2022	Raft/ Wall	M 30	390 kg/cm2	400.00	410.37	
	F.147/325/2021						413.33		
35.1	F.147/326/2021						422.22		do
	F.147/327/2021	13-11-2022	11/12/2022	Raft/ Wall	M30	390 kg/cm2	408.88	416.29	
	F.147/328/2021						417.77		
35.2	F.147/329/2021						417.77		do
	F.147/330/2021	13-11-2022	11/12/2022	Raft/ Wall	M 30	390 kg/cm2	417.77	416.29	
	F.147/331/2021						413.33		
36.1	F.147/332/2021						413.33		do
	F.147/333/2021	14-11-2022	12/12/2022	Raft/ Wall	M 30	390 kg/cm2	422.22	414.81	
	F.147/334/2021						408.88		
36.2	F.147/335/2021						417.77		do
	F.147/336/2021	14-11-2022	12/12/2022	Raft/ Wall	M 30	390 kg/cm2	404.44	414.81	
	F.147/337/2021						422.22		
36.3	F.147/338/2021						417.77		do
	F.147/339/2021	14-11-2022	12/12/2022	Raft/ Wall	M 30	390 kg/cm2	413.33	411.85	
	F.147/340/2021						404.44		
37.1	F.147/341/2021						293.33		do
	F.147/342/2021	14-11-2022	12/12/2022	Bed PCC	M 20	275 kg/cm2	284.44	287.40	
	F.147/343/2021						284.44		
37.2	F.147/344/2021						288.89		do
	F.147/345/2021	14-11-2022	12/12/2022	Bed PCC	M 20	275 kg/cm2	280.00	287.41	
	F.147/346/2021						293.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
38.1	F.147/347/2021						408.88		No. WRD/SD I/WD II/ F.Esst/496/2022-23. <b>DATED: 18-11-2022.</b>
	F.147/348/2021	16-11-2022	14-12-2022	Raft/ Wall	M 30	390 kg/cm2	400.00	402.96	
	F.147/349/2021						400.00		
38.2	F.147/350/2021						408.88		
	F.147/351/2021	16-11-2022	14-12-2022	Raft/ Wall	M30	390 kg/cm2	395.55	404.44	do
	F.147/352/2021						408.88		
39.1	F.147/353/2021						413.33		
	F.147/354/2021	17-11-2022	15-12-2022	Raft/ Wall	M30	390 kg/cm2	400.00	407.40	do
	F.147/355/2021						408.88		
39.2	F.147/356/2021						417.77		
	F.147/357/2021	17-11-2022	15-12-2022	Raft/ Wall	M30	390 kg/cm2	404.44	408.88	do
	F.147/358/2021						404.44		
39.3	F.147/359/2021						413.33		
	F.147/360/2021	17-11-2022	15-12-2022	Raft/ Wall	M30	390 kg/cm2	413.33	410.37	do
	F.147/361/2021						404.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/79

. Dated:-24/12/22

GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts

and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
40.1	F.147/371/2021						293.33		No. WRD/SD I/WD II/ F.Esstt/504/2022-23. <b>DATED: 22-11-2022.</b>
	F.147/372/2021	14-11-2022	12/12/2022	Bed PCC	M 20	275 kg/cm <sup>2</sup>	288.89	293.33	
	F.147/373/2021						297.78		
40.2	F.147/374/2021						288.89		do
	F.147/375/2021	14-11-2022	12/12/2022	Bed PCC	M 20	275 kg/cm <sup>2</sup>	293.33	291.85	
	F.147/376/2021						293.33		
40.3	F.147/377/2021						297.78		do
	F.147/378/2021	14-11-2022	12/12/2022	Bed PCC	M 20	275 kg/cm <sup>2</sup>	284.44	291.85	
	F.147/379/2021						293.33		
41.1	F.147/380/2021						293.33		do
	F.147/381/2021	15-11-2022	13-12-2022	Bed PCC	M 20	275 kg/cm <sup>2</sup>	302.22	293.33	
	F.147/382/2021						284.44		
41.2	F.147/383/2021						297.78		do
	F.147/384/2021	15-11-2022	13-12-2022	Bed PCC	M 20	275 kg/cm <sup>2</sup>	293.33	294.81	
	F.147/385/2021						293.33		
41.3	F.147/386/2021						288.89		do
	F.147/387/2021	15-11-2022	13-12-2022	Bed PCC	M 20	275 kg/cm <sup>2</sup>	302.22	294.81	
	F.147/388/2021						293.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
42.1	F.147/389/2021						302.22		No. WRD/SD I/WD II/
	F.147/390/2021	18-11-2022	16-12-2022	Bed PCC	M 20	275 kg/cm2	288.87	296.29	F.Esstt/504/2022-23.
	F.147/391/2021						297.78		<b>DATED: 22-11-2022.</b>
42.2	F.147/392/2021						297.78		
	F.147/393/2021	18-11-2022	16-12-2022	Bed PCC	M 20	275 kg/cm2	288.89	294.82	do
	F.147/394/2021						297.78		
42.3	F.147/395/2021						302.22		
	F.147/396/2021	18-11-2022	16-12-2022	Bed PCC	M 20	275 kg/cm2	297.78	297.78	do
	F.147/397/2021						293.33		
43.1	F.147/398/2021						408.88		
	F.147/399/2021	19-11-2022	17-12-2022	Raft/ Wall	M30	390 kg/cm2	417.77	410.36	do
	F.147/400/2021						404.44		
43.2	F.147/401/2021						413.33		
	F.147/402/2021	19-11-2022	17-12-2022	Raft/ Wall	M30	390 kg/cm2	417.77	413.33	do
	F.147/403/2021						408.88		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
44.1	F.147/404/2021						413.33		No. WRD/SD I/WD II/
	F.147/405/2021	23-11-2022	21-12-2022	Raft/ walls	M 30	390 kg/cm2	408.88	413.33	F.Esst/563/22-23.
	F.147/406/2021						417.77		<b>DATED: 20-12-2022.</b>
44.2	F.147/407/2021						417.77		
	F.147/408/2021	23-11-2022	21-12-2022	Raft/ walls	M 30	390 kg/cm2	417.77	414.81	do
	F.147/409/2021						408.88		
44.3	F.147/410/2021						417.77		
	F.147/411/2021	23-11-2022	21-12-2022	Raft/ walls	M 30	390 kg/cm2	422.22	417.77	do
	F.147/412/2021						413.33		
44.4	F.147/413/2021						417.77		
	F.147/414/2021	23-11-2022	21-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	414.81	do
	F.147/415/2021						413.33		
45.1	F.147/416/2021						413.33		
	F.147/417/2021	24-11-2022	22-12-2022	Raft/ walls	M 30	390 kg/cm2	417.77	413.33	do
	F.147/418/2021						408.88		
45.2	F.147/419/2021						417.77		
	F.147/420/2021	24-11-2022	22-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	414.81	do
	F.147/421/2021						413.33		
45.3	F.147/422/2021						417.77		
	F.147/423/2021	24-11-2022	22-12-2022	Raft/ walls	M 30	390 kg/cm2	408.88	414.81	do
	F.147/424/2021						417.77		
46.1	F.147/425/2021						422.22		
	F.147/426/2021	28-11-2022	26-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	417.77	do
	F.147/427/2021						417.77		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**



**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
46.2	F.147/428/2021						417.77		No. WRD/SD I/WD II/ F.Esst/ <b>563</b> /22-23. <b>DATED: 20-12-2022.</b>
	F.147/429/2021	28-11-2022	26-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	414.81	
	F.147/430/2021						413.33		
46.3	F.147/431/2021						413.33		
	F.147/432/2021	28-11-2022	26-12-2022	Raft/ walls	M 30	390 kg/cm2	413..3	413.33	do
	F.147/433/2021						413.33		
47.1	F.147/434/2021						417.77		
	F.147/435/2021	29-11-2022	27-12-2022	Raft/ walls	M 30	390 kg/cm2	426.66	420.73	do
	F.147/436/2021						417.77		
47.2	F.147/437/2021						422.22		
	F.147/438/2021	29-11-2022	27-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	417.77	do
	F.147/439/2021						417.77		
47.3	F.147/440/2021						417.77		
	F.147/441/2021	29-11-2022	27-12-2022	Raft/ walls	M 30	390 kg/cm2	417.77	416.29	do
	F.147/442/2021						413.33		
47.4	F.147/443/2021						422.22		
	F.147/444/2021	29-11-2022	27-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	417.77	do
	F.147/445/2021						417.77		
48.1	F.147/446/2021						413.33		
	F.147/447/2021	30-11-2022	28-12-2022	Raft/ walls	M 30	390 kg/cm2	408.88	413.33	do
	F.147/448/2021						417.77		
48.2	F.147/449/2021						413.33		
	F.147/450/2021	30-11-2022	28-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	414.81	do
	F.147/451/2021						417.77		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
48.3	F.147/451/2021						417.77		No. WRD/SD I/WD II/ F.Esst/ <b>563</b> /22-23. <b>DATED: 20-12-2022.</b>
	F.147/452/2021	30-11-2022	28-12-2022	Raft/ walls	M 30	390 kg/cm2	408.88	413.33	
	F.147/453/2021						413.33		
48.4	F.147/454/2021						413.33		
	F.147/455/2021	30-11-2022	28-12-2022	Raft/ walls	M 30	390 kg/cm2	408.88	410.36	do
	F.147/456/2021						408.88		
49.1	F.147/457/2021						408.88		
	F.147/458/2021	1/12/2022	29-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	411.85	do
	F.147/459/2021						413.33		
49.2	F.147/460/2021						408.88		
	F.147/461/2021	1/12/2022	29-12-2022	Raft/ walls	M 30	390 kg/cm2	404.44	408.88	do
	F.147/462/2021						413.33		
49.3	F.147/463/2021						413.33		
	F.147/464/2021	1/12/2022	29-12-2022	Raft/ walls	M 30	390 kg/cm2	408.88	411.85	do
	F.147/465/2021						413.33		
50.1	F.147/466/2021						422.22		
	F.147/467/2021	3/12/2022	31-12-2022	Raft/ walls	M 30	390 kg/cm2	422.22	420.74	do
	F.147/468/2021						417.77		
50.2	F.147/469/2021						417.77		
	F.147/470/2021	3/12/2022	31-12-2022	Raft/ walls	M 30	390 kg/cm2	422.22	422.22	do
	F.147/471/2021						426.66		
50.3	F.147/472/2021						422.22		
	F.147/473/2021	3/12/2022	31-12-2022	Raft/ walls	M 30	390 kg/cm2	417.77	419.25	do
	F.147/474/2021						417.77		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
50.4	F.147/475/2021						422.22		No. WRD/SD I/WD II/ F.Esst/563/22-23. <b>DATED: 20-12-2022.</b>
	F.147/476/2021	3/12/2022	31-12-2022	Raft/ walls	M 30	390 kg/cm2	413.33	417.77	
	F.147/477/2021						417.77		
51.1	F.147/478/2021						413.33		
	F.147/479/2021	4/12/2022	2/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	416.29	do
	F.147/480/2021						417.77		
51.2	F.147/481/2021						417.77		
	F.147/482/2021	4/12/2022	2/1/2023	Raft/ walls	M 30	390 kg/cm2	408.88	413.33	do
	F.147/483/2021						413.33		
51.3	F.147/484/2021						417.77		
	F.147/485/2021	4/12/2022	2/1/2023	Raft/ walls	M 30	390 kg/cm2	413.33	416.29	do
	F.147/486/2021						417.77		
52.1	F.147/487/2021						422.22		
	F.147/488/2021	5/12/2022	2/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	414.81	do
	F.147/489/2021						404.44		
52.2	F.147/490/2021						417.77		
	F.147/491/2021	5/12/2022	2/1/2023	Raft/ walls	M 30	390 kg/cm2	422.22	417.77	do
	F.147/492/2021						413.33		
52.3	F.147/493/2021						417.77		
	F.147/494/2021	5/12/2022	2/1/2023	Raft/ walls	M 30	390 kg/cm2	408.88	413.33	do
	F.147/495/2021						413.33		
53.1	F.147/496/2021						417.77		
	F.147/497/2021	6/12/2022	3/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	416.29	do
	F.147/498/2021						413.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
53.2	F.147/499/2021						413.33		No. WRD/SD I/WD II/ F.Esst/563/22-23. <b>DATED: 20-12-2022.</b>
	F.147/500/2021	6/12/2022	3/1/2023	Raft/ walls	M 30	390 kg/cm2	422.22	417.77	
	F.147/501/2021						417.77		
53.3	F.147/502/2021						422.22		do
	F.147/503/2021	6/12/2022	3/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	419.25	
	F.147/504/2021						417.77		
53.4	F.147/505/2021						413.33		do
	F.147/506/2021	6/12/2022	3/1/2023	Raft/ walls	M 30	390 kg/cm2	404.44	413.33	
	F.147/507/2021						422.22		
54.1	F.147/508/2021						413.33		do
	F.147/509/2021	7/12/2022	4/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	413.33	
	F.147/510/2021						408.88		
54.2	F.147/511/2021						417.77		do
	F.147/512/2021	7/12/2022	4/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	416.29	
	F.147/513/2021						413.33		
54.3	F.147/514/2021						417.77		do
	F.147/515/2021	7/12/2022	4/1/2023	Raft/ walls	M 30	390 kg/cm2	404.44	411.85	
	F.147/516/2021						413.33		
54.4	F.147/517/2021						413.33		do
	F.147/518/2021	7/12/2022	4/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	414.81	
	F.147/519/2021						413.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
55.1	F.147/520/2021						422.22		No. WRD/SD I/WD II/ F.Esst/563/22-23. <b>DATED: 20-12-2022.</b>
	F.147/521/2021	8/12/2022	5/1/2023	Raft/ walls	M 30	390 kg/cm2	408.88	416.29	
	F.147/522/2021						417.77		
55.2	F.147/523/2021						417.77		do
	F.147/524/2021	8/12/2022	5/1/2023	Raft/ walls	M 30	390 kg/cm2	422.22	417.77	
	F.147/525/2021						413.33		
55.3	F.147/526/2021						417.77		do
	F.147/527/2021	8/12/2022	5/1/2023	Raft/ walls	M 30	390 kg/cm2	422.22	419.25	
	F.147/528/2021						417.77		
56.1	F.147/529/2021						413.33		do
	F.147/530/2021	9/12/2022	6/1/2023	Raft/ walls	M 30	390 kg/cm2	413.33	414.81	
	F.147/531/2021						417.77		
56.2	F.147/532/2021						408.88		do
	F.147/533/2021	9/12/2022	6/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	413.33	
	F.147/534/2021						413.33		
56.3	F.147/535/2021						417.77		do
	F.147/536/2021	9/12/2022	6/1/2023	Raft/ walls	M 30	390 kg/cm2	426.66	420.73	
	F.147/537/2021						417.77		
56.4	F.147/538/2021						417.77		do
	F.147/539/2021	9/12/2022	6/1/2023	Raft/ walls	M 30	390 kg/cm2	417.77	416.29	
	F.147/540/2021						413.33		
57.1	F.147/541/2021						413.33		do
	F.147/542/2021	10/12/2022	7/1/2023	Raft/ walls	M 30	390 kg/cm2	408.88	411.85	
	F.147/543/2021						413.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
57.2	F.147/544/2021						417.77		No. WRD/SD I/WD II/ F.Esst/563/22-23. <b>DATED: 20-12-2022.</b>
	F.147/545/2021	10/12/2022	7/1/2023	Raft/ walls	M 30	390 kg/cm2	413.33	413.33	
	F.147/546/2021						408.88		
57.3	F.147/547/2021						413.33		do
	F.147/548/2021	10/12/2022	7/1/2023	Raft/ walls	M 30	390 kg/cm2	413.33	411.85	
	F.147/549/2021						408.88		
58.1	F.147/550/2021						422.22		do
	F.147/551/2021	16-12-2022	13-01-2023	Raft/ walls	M 30	390 kg/cm2	422.22	419.26	
	F.147/552/2021						413.33		
58.2	F.147/553/2021						417.77		do
	F.147/554/2021	16-12-2022	13-01-2023	Raft/ walls	M 30	390 kg/cm2	422.22	419.25	
	F.147/555/2021						417.77		
59.1	F.147/556/2021						413.33		do
	F.147/557/2021	17-12-2022	14-01-2023	Raft/ walls	M 30	390 kg/cm2	422.22	417.77	
	F.147/558/2021						417.77		
59.2	F.147/559/2021						417.77		do
	F.147/560/2021	17-12-2022	14-01-2023	Raft/ walls	M 30	390 kg/cm2	417.77	414.81	
	F.147/561/2021						408.88		
59.3	F.147/562/2021						422.22		do
	F.147/563/2021	17-12-2022	14-01-2023	Raft/ walls	M 30	390 kg/cm2	413.33	411.85	
	F.147/564/2021						400.00		
59.4	F.147/565/2021						417.77		do
	F.147/566/2021	17-12-2022	14-01-2023	Raft/ walls	M 30	390 kg/cm2	417.77	416.29	
	F.147/567/2021						413.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
59.5	F.147/568/2021						417.77		No. WRD/SD I/WD II/ F.Esst/563/22-23. <b>DATED: 20-12-2022.</b>
	F.147/569/2021	17-12-2022	14-01-2023	Raft/ walls	M 30	390 kg/cm2	413.33	413.33	
	F.147/570/2021						408.88		
60.1	F.147/571/2021						404.44		do
	F.147/572/2021	19-12-2022	16-01-2023	Raft/ walls	M 30	390 kg/cm2	417.77	413.33	
	F.147/573/2021						417.77		
60.2	F.147/574/2021						413.33		do
	F.147/575/2021	19-12-2022	16-01-2023	Raft/ walls	M 30	390 kg/cm2	413.33	414.81	
	F.147/576/2021						417.77		
60.3	F.147/577/2021						417.77		do
	F.147/578/2021	19-12-2022	16-01-2023	Raft/ walls	M 30	390 kg/cm2	417.77	417.77	
	F.147/579/2021						417.77		
61.1	F.147/580/2021						422.22		do
	F.147/581/2021	20-12-2022	17-01-2023	Raft/ walls	M 30	390 kg/cm2	417.77	419.25	
	F.147/582/2021						417.77		
61.2	F.147/583/2021						422.22		do
	F.147/584/2021	20-12-2022	17-01-2023	Raft/ walls	M 30	390 kg/cm2	422.22	420.74	
	F.147/585/2021						417.77		
61.3	F.147/586/2021						422.22		do
	F.147/587/2021	20-12-2022	17-01-2023	Raft/ walls	M 30	390 kg/cm2	413.33	417.77	
	F.147/588/2021						417.77		
61.4	F.147/589/2021						417.77		do
	F.147/590/2021	20-12-2022	17-01-2023	Raft/ walls	M 30	390 kg/cm2	422.22	420.74	
	F.147/591/2021						422.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

NO.WRD/WDXI/SDIII/TECH/W.F.147/2021/2022-23/121

. Dated:-04/02/2023

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
65.1	F.147/592/2021						422.22		No. WRD/SD I/WD II/ F.Esst/611/22-23. <b>DATED: 10-01-2023.</b>
	F.147/593/2021	21-12-2022	18-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	420.74	
	F.147/594/2021						417.77		
65.2	F.147/595/2021						413.33		do
	F.147/596/2021	21-12-2022	18-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	419.26	
	F.147/597/2021						422.22		
65.3	F.147/598/2021						417.77		do
	F.147/599/2021	21-12-2022	18-01-2023	Wall/ Slab	M 30	390 kg/cm2	413.33	417.77	
	F.147/600/2021						422.22		
66.1	F.147/601/2021						417.77		do
	F.147/602/2021	22-12-2022	19-01-2023	Wall/ Slab	M 30	390 kg/cm2	408.88	414.81	
	F.147/603/2021						417.77		
66.2	F.147/604/2021						413.33		do
	F.147/605/2021	22-12-2022	19-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	417.77	
	F.147/606/2021						417.77		
66.3	F.147/607/2021						413.33		do
	F.147/608/2021	22-12-2022	19-01-2023	Wall/ Slab	M 30	390 kg/cm2	417.77	416.29	
	F.147/609/2021						417.77		
67.1	F.147/610/2021						417.77		do
	F.147/611/2021	26-12-2022	23-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	419.25	
	F.147/612/2021						417.77		
67.2	F.147/613/2021						422.22		do
	F.147/614/2021	26-12-2022	23-01-2023	Wall/ Slab	M 30	390 kg/cm2	417.77	422.22	
	F.147/615/2021						426.66		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts



and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
67.3	F.147/616/2021						422.22		No. WRD/SD I/WD II/ F.Esstt/611/2022-23. <b>DATED: 10-01-2023.</b>
	F.147/617/2021	26-12-2022	23-01-2023	Wall/ Slab	M 30	390 kg/cm2	413.33	419.26	
	F.147/618/2021						422.22		
67.4	F.147/619/2021						417.77		do
	F.147/620/2021	26-12-2022	23-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	417.77	
	F.147/621/2021						413.33		
68.1	F.147/622/2021						413.33		do
	F.147/623/2021	27-12-2022	24-01-2023	Wall/ Slab	M 30	390 kg/cm2	417.77	416.29	
	F.147/624/2021						417.77		
68.2	F.147/625/2021						417.77		do
	F.147/626/2021	27-12-2022	24-01-2023	Wall/ Slab	M 30	390 kg/cm2	408.88	414.81	
	F.147/627/2021						417.77		
68.3	F.147/628/2021						417.77		do
	F.147/629/2021	27-12-2022	24-01-2023	Wall/ Slab	M 30	390 kg/cm2	413.33	416.29	
	F.147/630/2021						417.77		
68.4	F.147/631/2021						413.33		do
	F.147/632/2021	27-12-2022	24-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	417.77	
	F.147/633/2021						417.77		
69.1	F.147/634/2021						417.77		do
	F.147/635/2021	28-12-2022	25-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	420.74	
	F.147/636/2021						422.22		
69.2	F.147/637/2021						413.33		do
	F.147/638/2021	28-12-2022	25-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	411.85	
	F.147/639/2021						400.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts

and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
69.3	F.147/640/2021						417.77		No. WRD/SD I/WD II/ F.Esst/611/2022-23. <b>DATED: 10-01-2023.</b>
	F.147/641/2021	28-12-2022	25-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	413.33	413.33	
	F.147/642/2021						408.88		
70.1	F.147/643/2021						417.77		do
	F.147/644/2021	29-12-2022	26-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	417.77	417.77	
	F.147/645/2021						417.77		
70.2	F.147/646/2021						413.33		do
	F.147/647/2021	29-12-2022	26-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	417.77	416.29	
	F.147/648/2021						417.77		
70.3	F.147/649/2021						422.22		do
	F.147/650/2021	29-12-2022	26-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	417.77	417.77	
	F.147/651/2021						413.33		
70.4	F.147/652/2021						413.33		do
	F.147/653/2021	29-12-2022	26-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	413.33	414.81	
	F.147/654/2021						417.77		
71.1	F.147/655/2021						408.88		do
	F.147/656/2021	30-12-2022	27-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	417.77	413.33	
	F.147/657/2021						413.33		
71.2	F.147/658/2021						417.77		do
	F.147/659/2021	30-12-2022	27-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	413.33	417.77	
	F.147/660/2021						422.22		
71.3	F.147/661/2021						408.88		do
	F.147/662/2021	30-12-2022	27-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	417.77	414.81	
	F.147/663/2021						417.77		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts

and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
71.4	F.147/664/2021						422.22		No. WRD/SD I/WD II/ F.Esst/611/2022-23. <b>DATED: 10-01-2023.</b>
	F.147/665/2021	30-12-2022	27-01-2023	Wall/ Slab	M 30	390 kg/cm2	413.33	417.77	
	F.147/666/2021						417.77		
72.1	F.147/667/2021						413.33		do
	F.147/668/2021	31-12-2022	28-01-2023	Wall/ Slab	M 30	390 kg/cm2	408.88	411.85	
	F.147/669/2021						413.33		
72.2	F.147/670/2021						417.77		do
	F.147/671/2021	31-12-2022	28-01-2023	Wall/ Slab	M 30	390 kg/cm2	413.33	414.81	
	F.147/672/2021						413.33		
72.3	F.147/673/2021						417.77		do
	F.147/674/2021	31-12-2022	28-01-2023	Wall/ Slab	M 30	390 kg/cm2	417.77	416.29	
	F.147/675/2021						413.33		
73.1	F.147/676/2021						413.33		do
	F.147/677/2021	1/1/2023	29-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	417.77	
	F.147/678/2021						417.77		
73.2	F.147/679/2021						422.22		do
	F.147/680/2021	1/1/2023	29-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	419.26	
	F.147/681/2021						413.33		
73.3	F.147/682/2021						417.77		do
	F.147/683/2021	1/1/2023	29-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	420.74	
	F.147/684/2021						422.22		
74.1	F.147/685/2021						417.77		do
	F.147/686/2021	2/1/2023	30-01-2023	Wall/ Slab	M 30	390 kg/cm2	422.22	414.81	
	F.147/687/2021						404.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts

and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
74.2	F.147/688/2021						417.77		No. WRD/SD I/WD II/
	F.147/689/2021	2/1/2023	30-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	413.33	416.29	F.Esstt/611/2022-23.
	F.147/690/2021						417.77		<b>DATED: 10-01-2023.</b>
74.3	F.147/691/2021						417.77		
	F.147/692/2021	2/1/2023	30-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	417.77	417.77	do
	F.147/693/2021						417.77		
74.4	F.147/694/2021						413.33		
	F.147/695/2021	2/1/2023	30-01-2023	Wall/ Slab	M 30	390 kg/cm <sup>2</sup>	413.33	414.81	do
	F.147/696/2021						417.77		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**