

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to existing nallah near Manovikas School at Gogal in Fatorda Assembly Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogal - Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.22/06/2024						235.56		No. 353/SD III/WD III/ WRD/24-25/337. DATED: 27-12-2024
	F.22/07/2024	4/12/2024	1/1/2025	Base PCC	1.2.4	210 kg/cm2	226.67	229.63	
	F.22/08/2024						226.67		
1.2	F.22/09/2024						231.11		
	F.22/10/2024	4/12/2024	1/1/2025	Base PCC	1.2.4	210 kg/cm2	217.78	228.15	do
	F.22/11/2024						235.56		
2.1	F.22/12/2024						231.11		
	F.22/13/2024	6/12/2024	3/1/2025	Base Foundation 1	1.2.4	210 kg/cm2	240.00	231.11	do
	F.22/14/2024						222.22		
2.2	F.22/15/2024						231.11		
	F.22/16/2024	6/12/2024	3/1/2025	Base Foundation 1	1.2.4	210 kg/cm2	235.56	231.11	do
	F.22/17/2024						226.67		
3.1	F.22/18/2024						226.67		
	F.22/19/2024	10/12/2024	7/1/2025	Base Foundation 2	1.2.4	210 kg/cm2	231.11	232.59	do
	F.22/20/2024						240.00		
3.2	F.22/21/2024						235.56		
	F.22/22/2024	10/12/2024	7/1/2025	Base Foundation 2	1.2.4	210 kg/cm2	235.56	231.11	do
	F.22/23/2024						222.22		
4.1	F.22/24/2024						226.67		
	F.22/25/2024	12/12/2024	9/1/2025	Retaining wall 1	1.2.4	210 kg/cm2	231.11	231.11	do
	F.22/26/2024						235.56		
4.2	F.22/27/2024						231.11		
	F.22/28/2024	12/12/2024	9/1/2025	Retaining wall 1	1.2.4	210 kg/cm2	217.78	228.15	do
	F.22/29/2024						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to existing nallah near Manovikas School at Gogal in Fatorda Assembly Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogal - Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.22/30/2024						226.67		No. 353/SD III/WD III/ WRD/24-25/337. DATED: 27-12-2024
	F.22/31/2024	16-12-2024	13-01-2025	Retaining wall 2	1.2.4	210 kg/cm2	222.22	226.67	
	F.22/32/2024						231.11		
5.2	F.22/33/2024						235.56		
	F.22/34/2024	16-12-2024	13-01-2025	Retaining wall 2	1.2.4	210 kg/cm2	226.67	228.15	do
	F.22/35/2024						222.22		
6.1	F.22/36/2024						226.67		
	F.22/37/2024	18-12-2024	15-01-2025	R.1st Lift 1	1.2.4	210 kg/cm2	222.22	223.70	do
	F.22/38/2024						222.22		
6.2	F.22/39/2024						231.11		
	F.22/40/2024	18-12-2024	15-01-2025	R.1st Lift 1	1.2.4	210 kg/cm2	226.67	225.19	do
	F.22/41/2024						217.78		
7.1	F.22/42/2024						235.56		
	F.22/43/2024	23-12-2024	20-01-2025	R.1st Lift 2	1.2.4	210 kg/cm2	226.67	228.15	do
	F.22/44/2024						222.22		
7.2	F.22/45/2024						231.11		
	F.22/46/2024	23-12-2024	20-01-2025	R.1st Lift 2	1.2.4	210 kg/cm2	235.56	226.67	do
	F.22/47/2024						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER