

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of RHS side Protection wall at Cortalim Velipwada V.P. Uguem in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F. 07/06/2023						231.11		No. WRD/ SD I/ WD XII/ F.47/408/2023-24. DATED: 18-12-2023
	F. 07/07/2023	5/12/2023	2/1/2024	Foundation Ch. 0.00 m to 9.00 m	1.2.4	210 kg/cm2	222.22	226.67	
	F. 07/08/2023						226.67		
2	F. 07/09/2023						217.78		
	F. 07/10/2023	6/12/2023	3/1/2024	Foundation Ch. 9.00 m to 18.00 m	1.2.4	210 kg/cm2	235.56	226.67	do
	F. 07/11/2023						226.67		
3	F. 07/12/2023						231.11		
	F. 07/13/2023	7/12/2023	4/1/2024	Foundation Ch. 18.00 m to 27.00 m	1.2.4	210 kg/cm2	226.67	228.15	do
	F. 07/14/2023						226.67		
4	F. 07/15/2023						231.11		
	F. 07/16/2023	7/12/2023	4/1/2024	Foundation Ch. 27.00 m to 36.00 m	1.2.4	210 kg/cm2	226.67	231.11	do
	F. 07/17/2023						235.56		
5	F. 07/18/2023						222.22		
	F. 07/19/2023	9/12/2023	6/1/2024	1st Lift Ch. 0.00 m to 10.00 m	1.2.4	210 kg/cm2	235.56	228.15	do
	F. 07/20/2023						226.67		
6	F. 07/21/2023						231.11		
	F. 07/22/2023	9/12/2023	6/1/2024	1st Lift Ch. 10.00 m to 20.00 m	1.2.4	210 kg/cm2	235.56	229.63	do
	F. 07/23/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of RHS side Protection wall at Cortalim Velipwada V.P. Uguem in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
7	F. 07/24/2023						226.67		No. WRD/ SD I/ WD XII/
	F. 07/25/2023	9/12/2023	6/1/2024	1st Lift Ch. 20.00 m to 30.00 m	1.2.4	210 kg/cm ²	235.56	226.67	F.47/408/2023-24.
	F. 07/25/2023						217.78		DATED: 18-12-2023
8	F. 07/26/2023						231.11		
	F. 07/27/2023	11/12/2023	8/1/2024	1st Lift Ch. 30.00 m to 36.00 m	1.2.4	210 kg/cm ²	240.00	231.11	do
	F. 07/28/2023			2nd Lift Ch. 0.00 m to 5.00 m			222.22		
9	F. 07/29/2023						231.11		
	F. 07/29/2023	11/12/2023	8/1/2024	2nd Lift Ch. 5.00 m to 18.00 m	1.2.4	210 kg/cm ²	226.67	229.63	do
	F. 07/30/2023						231.11		
10	F. 07/31/2023						235.56		
	F. 07/32/2023	11/12/2023	8/1/2024	2nd Lift Ch. 18.00 m to 36.00 m	1.2.4	210 kg/cm ²	222.22	228.15	do
	F. 07/33/2023						226.67		
11	F. 07/34/2023						231.11		
	F. 07/35/2023	12/12/2023	9/1/2024	3rd Lift Ch. 0.00 m to 36.00 m	1.2.4	210 kg/cm ²	213.33	226.67	do
	F. 07/36/2023						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER