

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	295						106.67		No. WRD/WD X
1	296	12-11-2019	09-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	111.11	109.63	/SD I/WF.10/145/ 2019-20
	297						111.11		
	298						111.11		Dt.14/11/2019
2	299	13-11-2019	10-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	111.11	109.63	do
	300						106.67		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	313						262.22		No. WRD/WD X
1	314	14-11-2019	11-12-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	265 kg/cm2	266.67	265.19	/SD I/WF.10/149/
	315						266.67		/149/2019-20
	316						271.11		Dt.16/11/2019
2	317	14-11-2019	11-12-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	265 kg/cm2	271.11	268.15	do
	318						262.22		
	319						266.67		
3	320	15-11-2019	12-12-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	265 kg/cm2	266.67	266.67	do
	321						266.67		
	322						262.22		
3	323	15-11-2019	12-12-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	265 kg/cm2	266.67	265.19	do
	324						266.67		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)