

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	289						80.00		No. WRD/WD X
1	290	12-11-2019	19-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	80.00	80.00	/SD I/WF.10/145/
	291						80.00		2019-20
	292						80.00		Dt.14/11/2019
2	293	13-11-2019	20-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	84.44	81.48	do
	294						80.00		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	301						173.33		No. WRD/WD X
1	302	14-11-2019	21-11-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	175 kg/cm2	177.78	176.30	/SD I/WF.10/149/
	303						177.78		/149/2019-20
	304						182.22		Dt.16/11/2019
2	305	14-11-2019	21-11-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	175 kg/cm2	182.22	179.26	do
	306						173.33		
	307						177.78		
3	308	15-11-2019	22-11-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	175 kg/cm2	177.78	177.78	do
	309						177.78		
	310						173.33		
3	311	15-11-2019	22-11-2019	7.50 cm R.C.C Canal Lining	1.1.5.3	175 kg/cm2	182.22	179.26	do
	312						182.22		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)