

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of nallah behind PM Dias Residency Co-Op housing Society Ltd to Rajiv Shinkre house at Borda in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 16/05/2023						222.22		No. 333/ SD III/ WD III/ WRD/23-24/ 371 . DATED: 14-12-2023
	F. 16/06/2023	30-11-2023	28-12-2023	Nallah Fdn Ch 0 to 120 m	1.2.4	210 kg/cm2	231.11	229.63	
	F. 16/07/2023						235.56		
1.2	F. 16/08/2023						217.78		
	F. 16/09/2023	30-11-2023	28-12-2023	Nallah Fdn Ch 0 to 120 m	1.2.4	210 kg/cm2	235.56	231.11	do
	F. 16/10/2023						240.00		
2.1	F. 16/11/2023						284.44		
	F. 16/12/2023	2/12/2023	30-12-2023	Nallah Raft Ch 0 m to 60 m	1.1.5.3	265 kg/cm2	293.33	282.96	do
	F. 16/13/2023						271.11		
2.2	F. 16/14/2023						288.89		
	F. 16/15/2023	2/12/2023	30-12-2023	Nallah Raft Ch 0 m to 60 m	1.1.5.3	265 kg/cm2	284.44	284.44	do
	F. 16/16/2023						280.00		
3.1	F. 16/17/2023						293.33		
	F. 16/18/2023	5/12/2023	2/1/2024	Nallah Raft Ch 60 m to 120 m	1.1.5.3	265 kg/cm2	280.00	287.41	do
	F. 16/19/2023						288.89		
3.2	F. 16/20/2023						284.44		
	F. 16/21/2023	5/12/2023	2/1/2024	Nallah Raft Ch 60 m to 120 m	1.1.5.3	265 kg/cm2	275.56	285.93	do
	F. 16/22/2023						297.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of nallah behind PM Dias Residency Co-Op housing Society Ltd to Rajiv Shinkre house at Borda in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F. 16/23/2023						293.33		No. 333/ SD III/ WD III/
	F. 16/24/2023	7/12/2023	4/1/2024	Nallah wall Ch 0 m to 60 m	1.1.5.3	265 kg/cm2	280.00	287.41	WRD/23-24/ 371 .
	F. 16/25/2023						288.89		DATED: 14-12-2023
4.2	F. 16/25/2023						284.44		
	F. 16/26/2023	7/12/2023	4/1/2024	Nallah wall Ch 0 m to 60 m	1.1.5.3	265 kg/cm2	288.89	288.89	do
	F. 16/27/2023						293.33		
5.1	F. 16/28/2023						297.78		
	F. 16/29/2023	12/12/2023	9/1/2024	Nallah wall Ch 60 m to 120 m	1.1.5.3	265 kg/cm2	280.00	290.37	do
	F. 16/29/2023						293.33		
5.2	F. 16/30/2023						293.33		
	F. 16/31/2023	12/12/2023	9/1/2024	Nallah wall Ch 60 m to 120 m	1.1.5.3	265 kg/cm2	288.89	293.33	do
	F. 16/32/2023						297.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER