

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Raising and Augmentation of existing protection wall on LHS banks of lake nallah near PWD road culvert at Bansai Kakoda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.15/06/2024						235.56		No. WRD/WDXII/SDV/ F.70/166/2024-25. DATED: 27-12-2024
	F.15/07/2024	9/12/2024	6/1/2025	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.15/08/2024						222.22		
1.2	F.15/09/2024						231.11		do
	F.15/10/2024	9/12/2024	6/1/2025	Foundation	1.2.4	210 kg/cm2	222.22	228.15	
	F.15/11/2024						231.11		
1.3	F.15/12/2024						235.56		do
	F.15/13/2024	9/12/2024	6/1/2025	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.15/14/2024						217.78		
2.1	F.15/15/2024						226.67		do
	F.15/16/2024	10/12/2024	7/1/2025	Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F.15/17/2024						235.56		
2.2	F.15/18/2024						240.00		do
	F.15/19/2024	10/12/2024	7/1/2025	Foundation	1.2.4	210 kg/cm2	217.78	228.15	
	F.15/20/2024						226.67		
2.3	F.15/21/2024						231.11		do
	F.15/22/2024	10/12/2024	7/1/2025	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F.15/23/2024						231.11		
3.1	F.15/24/2024						231.11		do
	F.15/25/2024	12/12/2024	9/1/2025	Foundation (RCC)	1.2.4	210 kg/cm2	235.56	229.63	
	F.15/26/2024						222.22		
3.2	F.15/27/2024						226.67		do
	F.15/28/2024	12/12/2024	9/1/2025	Foundation (RCC)	1.2.4	210 kg/cm2	235.56	228.15	
	F.15/29/2024						222.22		

Carrie Correia
JUNIOR ENGINEER.

S.S. Velingkar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Raising and Augmentation of existing protection wall on LHS banks of lake nallah near PWD road culvert at Bansai Kakoda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
3.3	F.15/30/2024						240.00		No. WRD/WDXII/SDV/ F.70/166/2024-25. DATED: 27-12-2024
	F.15/31/2024	12/12/2024	9/1/2025	Foundation (RCC)	1.2.4	210 kg/cm ²	231.11	231.11	
	F.15/32/2024						222.22		
4.1	F.15/33/2024						226.67		
	F.15/34/2024	14-12-2024	13-01-2025	1st Lift	1.2.4	210 kg/cm ²	222.22	225.19	do
	F.15/35/2024						226.67		
4.2	F.15/36/2024						231.11		
	F.15/37/2024	14-12-2024	13-01-2025	1st Lift	1.2.4	210 kg/cm ²	222.22	229.63	do
	F.15/38/2024						235.56		
4.3	F.15/39/2024						235.56		
	F.15/40/2024	14-12-2024	13-01-2025	1st Lift	1.2.4	210 kg/cm ²	226.67	228.15	do
	F.15/41/2024						222.22		
5.1	F.15/42/2024						235.56		
	F.15/43/2024	16-12-2024	13-01-2025	2nd Lift	1.2.4	210 kg/cm ²	226.67	231.11	do
	F.15/44/2024						231.11		
5.2	F.15/45/2024						222.22		
	F.15/46/2024	16-12-2024	13-01-2025	2nd Lift	1.2.4	210 kg/cm ²	226.67	229.63	do
	F.15/47/2024						240.00		
5.3	F.15/49/2024						231.11		
	F.15/50/2024	16-12-2024	13-01-2025	2nd Lift	1.2.4	210 kg/cm ²	244.44	231.11	do
	F.15/51/2024						217.78		

Carrie Correia
JUNIOR ENGINEER.

S.S. Velingkar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Raising and Augmetation of existing protection wall on LHS banks of lake nallah near PWD road culvert at Bansai Kakoda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.15/52/2024						226.67		No. WRD/WDXII/SDV/ F.70/166/2024-25. DATED: 27-12-2024
	F.15/53/2024	18-12-2024	15-01-2025	3rd Lift	1.2.4	210 kg/cm2	231.11	228.15	
	F.15/54/2024						226.67		
6.2	F.15/55/2024						222.22		do
	F.15/56/2024	18-12-2024	15-01-2025	3rd Lift	1.2.4	210 kg/cm2	226.67	225.19	
	F.15/57/2024						226.67		
6.3	F.15/58/2024						231.11		do
	F.15/59/2024	18-12-2024	15-01-2025	3rd Lift	1.2.4	210 kg/cm2	226.67	226.67	
	F.15/60/2024						222.22		
7.1	F.15/61/2024						240.00		do
	F.15/62/2024	20-12-2024	17-01-2025	4th Lift	1.2.4	210 kg/cm2	226.67	232.59	
	F.15/63/2024						231.11		
7.2	F.15/64/2024						235.56		do
	F.15/65/2024	20-12-2024	17-01-2025	4th Lift	1.2.4	210 kg/cm2	231.11	231.11	
	F.15/66/2024						226.67		
7.3	F.15/67/2024						244.44		do
	F.15/68/2024	20-12-2024	17-01-2025	4th Lift	1.2.4	210 kg/cm2	231.11	234.07	
	F.15/69/2024						226.67		

Carrie Correia
JUNIOR ENGINEER.

S.S. Velingkar
ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F. 15-2024/2024-25/ 304

. Dated:-27/01/2025

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Raising and Augmentation of existing protection wall on LHS banks of lake nallah near PWD road culvert at Bansai Kakoda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.1	F.15/70/2024						226.67		No. WRD/SD V/WDXII/ F.70/168/2024-25. DATED: 28-12-2024
	F.15/71/2024	23/12/2024	20/1/2025	RCC	1.2.4	210 kg/cm2	231.11	225.19	
	F.15/72/2024						217.78		
8.2	F.15/73/2024						235.56		
	F.15/74/2024	23/12/2024	20/1/2025	RCC	1.2.4	210 kg/cm2	226.67	228.15	do
	F.15/75/2024						222.22		
9.1	F.15/76/2024						235.56		
	F.15/77/2024	24/12/2024	21/1/2025	RCC	1.2.4	210 kg/cm2	231.11	231.11	do
	F.15/78/2024						226.67		
9.2	F.15/79/2024						231.11		
	F.15/80/2024	24/12/2024	21/1/2025	RCC	1.2.4	210 kg/cm2	226.67	228.15	do
	F.15/81/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER