

NO.WRD/WDXI/SDIII/TECH/W.F. 15-2024/2024-25/304

. Dated:-27/01/2025

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Raising and Augmetation of existing protection wall on LHS banks of lake nallah near PWD road culvert at Bansai Kakoda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.15/88/2024						151.11		No. WRD/SD V/WDXII/ F.70/168/2024-25. DATED: 28-12-2024
	F.15/89/2024	23-12-2024	30-12-2024	RCC	1.2.4	140 kg/cm2	142.22	146.67	
	F.15/90/2024						146.67		
2	F.15/91/2024						142.22		do
	F.15/92/2024	24-12-2024	31-12-2024	RCC	1.2.4	140 kg/cm2	155.56	149.63	
	F.15/93/2024						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER