

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank near the house of Bal Sahakari in V.P. Curti- Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.15/06/2023						102.22		No. WRD/WD XI/ SD IV/ F.CF/531/2023-24. DATED: 29-12-2023.
	F.15/07/2023	11/12/2023	8/1/2024	Foundation	1.3.6	100 kg/cm2	115.56	109.63	
	F.15/08/2023						111.11		
1.2	F.15/09/2023						111.11		
	F.15/10/2023	11/12/2023	8/1/2024	Foundation	1.3.6	100 kg/cm2	106.67	109.63	do
	F.15/11/2023						111.11		
2.1	F.15/12/2023						111.11		
	F.15/13/2023	12/12/2023	9/1/2024	Foundation	1.3.6	100 kg/cm2	102.22	108.15	do
	F.15/14/2023						111.11		
2.2	F.15/15/2023						120.00		
	F.15/16/2023	12/12/2023	9/1/2024	Foundation	1.3.6	100 kg/cm2	115.56	115.56	do
	F.15/17/2023						111.11		
3.1	F.15/18/2023						111.11		
	F.15/19/2023	13-12-2023	10/1/2024	1st Lift	1.3.6	100 kg/cm2	106.67	111.11	do
	F.15/20/2023						115.56		
3.2	F.15/21/2023						111.11		
	F.15/22/2023	13-12-2023	10/1/2024	1st Lift	1.3.6	100 kg/cm2	111.11	109.63	do
	F.15/23/2023						106.67		
4.1	F.15/24/2023						120.00		
	F.15/25/2023	14-12-2023	11/1/2024	1st Lift	1.3.6	100 kg/cm2	106.67	112.59	do
	F.15/26/2023						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank near the house of Bal Sahakari in V.P. Curti- Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
4.2	F.15/27/2023						124.44		No. WRD/WD XI/ SD IV/ F.CF/531/2023-24. DATED: 29-12-2023.
	F.15/28/2023	14-12-2023	11/1/2024	1 st Lift	1.3.6	100 kg/cm ²	111.11	114.07	
	F.15/29/2023						106.67		
5.1	F.15/30/2023						111.11		
	F.15/31/2023	15-12-2023	12/1/2024	II nd Lift	1.3.6	100 kg/cm ²	106.67	111.11	do
	F.15/32/2023						115.56		
5.2	F.15/33/2023						102.22		
	F.15/34/2023	15-12-2023	12/1/2024	II nd Lift	1.3.6	100 kg/cm ²	106.67	108.15	do
	F.15/35/2023						115.56		
6.1	F.15/36/2023						111.11		
	F.15/37/2023	16-12-2023	15-01-2024	II nd Lift	1.3.6	100 kg/cm ²	111.11	109.63	do
	F.15/38/2023						106.67		
6.2	F.15/39/2023						115.56		
	F.15/40/2023	16-12-2023	15-01-2024	II nd Lift	1.3.6	100 kg/cm ²	111.11	109.63	do
	F.15/41/2023						102.22		
7.1	F.15/42/2023						102.22		
	F.15/43/2023	18-12-2023	15-01-2024	III rd Lift	1.3.6	100 kg/cm ²	106.67	106.67	do
	F.15/44/2023						111.11		
7.2	F.15/45/2023						115.56		
	F.15/46/2023	18-12-2023	15-01-2024	III rd Lift	1.3.6	100 kg/cm ²	102.22	108.15	do
	F.15/47/2023						106.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER