

NO.WRD/WDXI/SDIII/TECH/W.F. 38-Oct-2024/2024-25/307

Dated:-27/01/25

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of retaining wall behind house of Ernesto D'Souza, Alto Fondavem in Ward No. 30 at Raibandar in Panaji- Goa.

**SAMPLE SENT BY:** AE, SD IV, WD I, WRD, Porvorim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.38/06/2024						231.11		No. SD IV/ WD I/WRD/ F.38/24-25/479. <b>DATED: 31-12-2024.</b>
	F.38/07/2024	16-12-2024	13-01-2025	Foundation	1.2.4	210 kg/cm2	235.56	231.11	
	F.38/08/2024						226.67		
1.2	F.38/09/2024						240.00		do
	F.38/10/2024	16-12-2024	13-01-2025	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.38/11/2024						217.78		
1.3	F.38/12/2024						235.56		do
	F.38/13/2024	16-12-2024	13-01-2025	Foundation	1.2.4	210 kg/cm2	231.11	232.59	
	F.38/14/2024						231.11		
2.1	F.38/15/2024						222.22		do
	F.38/16/2024	18-12-2024	15-01-2025	1 <sup>st</sup> Lift	1.2.4	210 kg/cm2	226.67	226.67	
	F.38/17/2024						231.11		
2.2	F.38/18/2024						235.56		do
	F.38/19/2024	18-12-2024	15-01-2025	1 <sup>st</sup> Lift	1.2.4	210 kg/cm2	231.11	231.11	
	F.38/20/2024						226.67		
2.3	F.38/21/2024						222.22		do
	F.38/22/2024	18-12-2024	15-01-2025	1 <sup>st</sup> Lift	1.2.4	210 kg/cm2	240.00	231.11	
	F.38/23/2024						231.11		
2.4	F.38/24/2024						240.00		do
	F.38/25/2024	18-12-2024	15-01-2025	1 <sup>st</sup> Lift	1.2.4	210 kg/cm2	231.11	232.59	
	F.38/26/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of retaining wall behind house of Ernesto D'Souza, Alto Fondavem in Ward No. 30 at Raibandar in Panaji- Goa.

**SAMPLE SENT BY:** AE, SD IV, WD I, WRD, Porvorim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.38/27/2024						226.67		No. SD IV/ WD I/WRD/ F.38/24-25/479. <b>DATED: 31-12-2024.</b>
	F.38/28/2024	21-12-2024	18-01-2025	II <sup>nd</sup> lift	1.2.4	210 kg/cm2	222.22	226.67	
	F.38/29/2024						231.11		
3.2	F.38/30/2024						235.56		
	F.38/31/2024	21-12-2024	18-01-2025	II <sup>nd</sup> lift	1.2.4	210 kg/cm2	226.67	229.63	do
	F.38/32/2024						226.67		
3.3	F.38/33/2024						231.11		
	F.38/34/2024	21-12-2024	18-01-2025	II <sup>nd</sup> lift	1.2.4	210 kg/cm2	235.56	228.15	do
	F.38/35/2024						217.78		
4.1	F.38/36/2024						235.56		
	F.38/37/2024	24-12-2024	21-01-2025	III <sup>rd</sup> Lift	1.2.4	210 kg/cm2	231.11	231.11	do
	F.38/38/2024						226.67		
4.2	F.38/39/2024						231.11		
	F.38/40/2024	24-12-2024	21-01-2025	III <sup>rd</sup> Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.38/41/2024						222.22		
4.3	F.38/42/2024						231.11		
	F.38/43/2024	24-12-2024	21-01-2025	III <sup>rd</sup> Lift	1.2.4	210 kg/cm2	235.56	229.63	do
	F.38/44/2024						222.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of retaining wall behind house of Ernesto D'Souza, Alto Fondavem in Ward No. 30 at Raibandar in Panaji- Goa.

**SAMPLE SENT BY:** AE, SD IV, WD I, WRD, Porvorim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
5.1	F.38/45/2024						222.22		No. SD IV/ WD I/WRD/ F.38/24-25/479. <b>DATED: 31-12-2024.</b>
	F.38/46/2024	26-12-2024	23-01-2025	IV <sup>th</sup> Lift	1.2.4	210 kg/cm <sup>2</sup>	226.67	226.67	
	F.38/47/2024						231.11		
5.2	F.38/49/2024						235.56		do
	F.38/50/2024	26-12-2024	23-01-2025	IV <sup>th</sup> Lift	1.2.4	210 kg/cm <sup>2</sup>	217.78	228.15	
	F.38/51/2024						231.11		
5.3	F.38/52/2024						226.67		do
	F.38/53/2024	26-12-2024	23-01-2025	IV <sup>th</sup> Lift	1.2.4	210 kg/cm <sup>2</sup>	235.56	229.63	
	F.38/54/2024						226.67		
6.1	F.38/55/2024						226.67		do
	F.38/56/2024	28-12-2024	25-01-2025	V <sup>th</sup> :Lift	1.2.4	210 kg/cm <sup>2</sup>	244.44	234.07	
	F.38/57/2024						231.11		
6.2	F.38/58/2024						231.11		do
	F.38/59/2024	28-12-2024	25-01-2025	V <sup>th</sup> :Lift	1.2.4	210 kg/cm <sup>2</sup>	235.56	231.11	
	F.38/60/2024						226.67		
7.1	F.38/61/2024						217.78		do
	F.38/62/2024	30-12-2024	27-01-2025	VI <sup>th</sup> Lift	1.2.4	210 kg/cm <sup>2</sup>	235.56	228.15	
	F.38/63/2024						231.11		
7.2	F.38/64/2024						226.67		do
	F.38/65/2024	30-12-2024	27-01-2025	VI <sup>th</sup> Lift	1.2.4	210 kg/cm <sup>2</sup>	231.11	229.63	
	F.38/66/2024						231.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**