

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization on the left bank of river Zuari in No.42/7 at Baag Shirfond in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.148/06/2021						151.11		No. WRD/WD XII/SD V/
	F.148/07/2021	9/9/2022	16-09-2022	LHS Base Foundation	1.2.4	140 kg/cm2	155.56	154.08	F.15/125/2022-23.
	F.148/08/2021						155.56		DATED: 16-09-2022.
2	F.148/09/2021						160.00		
	F.148/10/2021	10/9/2022	17-09-2022	Foundation	1.2.4	140 kg/cm2	155.56	157.04	do
	F.148/11/2021						155.56		
3	F.148/12/2021						146.67		
	F.148/13/2021	12/9/2022	19-09-2022	1st Lift	1.2.4	140 kg/cm2	142.22	145.19	do
	F.148/14/2021						146.67		
4	F.148/15/2021						151.11		
	F.148/16/2021	13-09-2022	20-09-2022	2nd Lift	1.2.4	140 kg/cm2	151.11	152.59	do
	F.148/17/2021						155.56		
5	F.148/18/2021						151.11		
	F.148/19/2021	14-09-2022	21-09-2022	3rd lift	1.2.4	140 kg/cm2	146.67	149.63	do
	F.148/20/2021						151.11		
6	F.148/21/2021						151.11		
	F.148/22/2021	15-09-2022	22-09-2022	4th lift	1.2.4	140 kg/cm2	151.11	152.59	do
	F.148/23/2021						155.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER