

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization on the left bank of river Zuari in No.42/7 at Baag Shirfond in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.148/24/2021						226.67		No. WRD/WD II/SD V/
	F.148/25/2021	9/9/2022	7/10/2022	LHS Base Foundation	1.2.4	210 kg/cm2	231.11	229.63	F.15/125/2022-23.
	F.148/26/2021						231.11		DATED: 16-09-2022.
2	F.148/27/2021						226.67		
	F.148/28/2021	10/9/2022	8/10/2022	Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.148/29/2021						231.11		
3	F.148/30/2021						226.67		
	F.148/31/2021	12/9/2022	10/10/2022	1st Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.148/32/2021						226.67		
4	F.148/33/2021						231.11		
	F.148/34/2021	13-09-2022	11/10/2022	2nd Lift	1.2.4	210 kg/cm2	217.78	222.22	do
	F.148/35/2021						217.78		
5	F.148/36/2021						231.11		
	F.148/37/2021	14-09-2022	12/10/2022	3rd lift	1.2.4	210 kg/cm2	226.67	228.15	do
	F.148/38/2021						226.67		
6	F.148/39/2021						226.67		
	F.148/40/2021	15-09-2022	13-10-2022	4th lift	1.2.4	210 kg/cm2	222.22	225.19	do
	F.148/41/2021						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER