

NO.WRD/WDXI/SDIII/TECH/W.F.31/2023/2023-24/317

. Dated:-27/01/24

GOVERNMENT OF GOA

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to the retaining wall of Kapileshwari nallah at Varkhand Haveli Junction in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD II, WD III, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**07 days.**

| REPORT NO | SAMPLE NOS.   | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH        | Comp sth in Kg/cm <sup>2</sup> | Avg. Comp Kg/cm <sup>2</sup> | LETTER No / DATED        |
|-----------|---------------|--------------|--------------|--------------------|----------------|------------------------|--------------------------------|------------------------------|--------------------------|
| 1         | F. 31/05/2023 |              |              |                    |                |                        | 146.67                         |                              | No.W.F. 31/SD II/WD III/ |
|           | F. 31/06/2023 | 15-01-2024   | 22-01-2024   | foundation         | 1.2.4          | 140 kg/cm <sup>2</sup> | 155.56                         | 148.15                       | WRD/23-24/ <b>331.</b>   |
|           | F. 31/07/2023 |              |              |                    |                |                        | 142.22                         |                              | <b>DATED: 20-01-2024</b> |
| 2         | F. 31/08/2023 |              |              |                    |                |                        | 146.67                         |                              |                          |
|           | F. 31/09/2023 | 18-01-2024   | 25-01-2024   | 1st Lift           | 1.2.4          | 140 kg/cm <sup>2</sup> | 146.67                         | 148.15                       | do                       |
|           | F. 31/10/2023 |              |              |                    |                |                        | 151.11                         |                              |                          |
| 3         | F. 31/11/2023 |              |              |                    |                |                        | 155.56                         |                              |                          |
|           | F. 31/12/2023 | 19-01-2024   | 27-01-2024   | 2nd Lift           | 1.2.4          | 140 kg/cm <sup>2</sup> | 137.78                         | 146.67                       | do                       |
|           | F. 31/13/2023 |              |              |                    |                |                        | 146.67                         |                              |                          |

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**