

NO.WRD/WDXI/SDIII/TECH/W.F. 49/2023/2023-24/327

. Dated:-13/02/2024

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of 4 nos of RCC Shallow wells in Nuvem Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.49/06/2023						297.78		No. 322/ SD III/ WD III/ WRD/23-24/ 458 DATED: 05-02-2024
	F.49/07/2023	10/1/2024	7/2/2024	Well Curb + 4 Rings	1.1.5.3	265 kg/cm2	293.33	294.81	
	F.49/08/2023						293.33		
2	F.49/09/2023						297.78		
	F.49/10/2023	12/1/2024	9/2/2024	5 Rings	1.1.5.3	265 kg/cm2	293.33	291.85	do
	F.49/11/2023						284.44		
3	F.49/12/2023						297.78		
	F.49/13/2023	15-01-2024	12/2/2024	6 Rings	1.1.5.3	265 kg/cm2	293.33	293.33	do
	F.49/14/2023						288.89		
4	F.49/15/2023						293.33		
	F.49/16/2023	16-01-2024	13-02-2024	5 Rings	1.1.5.3	265 kg/cm2	302.22	290.37	do
	F.49/17/2023						275.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER