

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to traditional Irrigation tank at Ambegan in Sy.No. 135 V.P. Panchwadi in Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.34/06/2023						226.67		No. WRD/WD XI/ SD IV/ W.F.434/620/2023-24. <b>DATED: 02-02-2024.</b>
	F.34/07/2023	5/1/2024	2/2/2024	Foundation Cut off	1.2.4	210 kg/cm2	226.67	228.15	
	F.34/08/2023						231.11		
1.2	F.34/09/2023						231.11		
	F.34/10/2023	5/1/2024	2/2/2024	Foundation Cut off	1.2.4	210 kg/cm2	231.11	229.63	do
	F.34/11/2023						226.67		
1.3	F.34/12/2023						235.56		
	F.34/13/2023	5/1/2024	2/2/2024	Foundation Cut off	1.2.4	210 kg/cm2	235.56	229.63	do
	F.34/14/2023						217.78		
2.1	F.34/15/2023						226.67		
	F.34/16/2023	6/1/2024	3/2/2024	Foundation / Apron	1.2.4	210 kg/cm2	213.33	225.19	do
	F.34/17/2023						235.56		
2.2	F.34/18/2023						231.11		
	F.34/19/2023	6/1/2024	3/2/2024	Foundation / Apron	1.2.4	210 kg/cm2	222.22	228.15	do
	F.34/20/2023						231.11		
2.3	F.34/21/2023						226.67		
	F.34/22/2023	6/1/2024	3/2/2024	Foundation / Apron	1.2.4	210 kg/cm2	226.67	228.15	do
	F.34/23/2023						231.11		
3.1	F.34/24/2023						222.22		
	F.34/25/2023	8/1/2024	5/2/2024	Foundation / Apron	1.2.4	210 kg/cm2	231.11	226.67	do
	F.34/26/2023						226.67		
3.2	F.34/27/2023						217.78		
	F.34/28/2023	8/1/2024	5/2/2024	Foundation / Apron	1.2.4	210 kg/cm2	226.67	223.71	do
	F.34/29/2023						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement to traditional Irrigation tank at Ambegan in Sy.No. 135 V.P. Panchwadi in Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.34/27/2023						226.67		No. WRD/WD XI/ SD IV/ W.F.434/620/2023-24. <b>DATED: 02-02-2024.</b>
	F.34/28/2023	8/1/2024	5/2/2024	Foundation / Apron	1.2.4	210 kg/cm2	231.11	228.15	
	F.34/29/2023						226.67		
4.1	F.34/30/2023						217.78		
	F.34/31/2023	9/1/2024	6/2/2024	Foundation/ Wall Concrete/ Abutment	1.2.4	210 kg/cm2	231.11	225.19	do
	F.34/32/2023						226.67		
4.2	F.34/33/2023						226.67		
	F.34/34/2023	9/1/2024	6/2/2024	Foundation/ Wall Concrete/ Abutment	1.2.4	210 kg/cm2	226.67	226.67	do
	F.34/35/2023						226.67		
4.3	F.34/36/2023						235.56		
	F.34/37/2023	9/1/2024	6/2/2024	Foundation/ Wall Concrete/ Abutment	1.2.4	210 kg/cm2	213.33	228.15	do
	F.34/38/2023						235.56		
5.1	F.34/39/2023						217.78		
	F.34/40/2023	11/1/2024	8/2/2024	Wall Concrete/ Abutment	1.2.4	210 kg/cm2	226.67	225.19	do
	F.34/41/2023						231.11		
5.2	F.34/42/2023						226.67		
	F.34/43/2023	11/1/2024	8/2/2024	Wall Concrete/ Abutment	1.2.4	210 kg/cm2	217.78	222.22	do
	F.34/44/2023						222.22		
5.3	F.34/45/2023						226.67		
	F.34/46/2023	11/1/2024	8/2/2024	Wall Concrete/ Abutment	1.2.4	210 kg/cm2	226.67	225.19	do
	F.34/47/2023						222.22		
5.4	F.34/49/2023						231.11		
	F.34/50/2023	11/1/2024	8/2/2024	Wall Concrete/ Abutment	1.2.4	210 kg/cm2	226.67	228.15	do
	F.34/51/2023						226.67		

**Carrie Correia**  
**JUNIOR ENGINEER.**

**S.S. Velingkar**  
**ASSISTANT ENGINEER**

**NO.WRD/WDXI/SDIII/TECH/W.F. 34/2023/2023-24/ 342**

**. Dated:-19/02/24**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to traditional Irrigation tank at Ambegan in Sy.No. 135 V.P. Panchwadi in Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.34/52/2023						231.11		No. WRD/WD XI/ SD IV/ W.F.434/ <b>645</b> /2023-24. <b>DATED: 13-02-2024.</b>
	F.34/53/2023	16-01-2024	13-02-2024	Wall Concrete	1.2.4	210 kg/cm2	222.22	226.67	
	F.34/54/2023						226.67		
1.2	F.34/55/2023						235.56		
	F.34/56/2023	16-01-2024	13-02-2024	Wall Concrete	1.2.4	210 kg/cm2	217.78	225.19	do
	F.34/57/2023						222.22		
1.3	F.34/58/2023						231.11		
	F.34/59/2023	16-01-2024	13-02-2024	Wall Concrete	1.2.4	210 kg/cm2	231.11	228.15	do
	F.34/60/2023						222.22		
2.1	F.34/61/2023						231.11		
	F.34/62/2023	18-01-2024	15-02-2024	Wall Concrete	1.2.4	210 kg/cm2	217.78	223.70	do
	F.34/63/2023						222.22		
2.2	F.34/64/2023						226.67		
	F.34/65/2023	18-01-2024	15-02-2024	Wall Concrete	1.2.4	210 kg/cm2	222.22	225.19	do
	F.34/66/2023						226.67		
2.3	F.34/67/2023						226.67		
	F.34/68/2023	18-01-2024	15-02-2024	Wall Concrete	1.2.4	210 kg/cm2	231.11	223.70	do
	F.34/69/2023						213.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement to traditional Irrigation tank at Ambegan in Sy.No. 135 V.P. Panchwadi in Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.34/70/2023						235.56		No. WRD/WD XI/ SD IV/ W.F.434/ <b>645</b> /2023-24. <b>DATED: 13-02-2024.</b>
	F.34/71/2023	20-01-2024	17-02-2024	Wall Concrete	1.2.4	210 kg/cm2	217.78	225.19	
	F.34/72/2023						222.22		
3.2	F.34/73/2023						231.11		
	F.34/74/2023	20-01-2024	17-02-2024	Wall Concrete	1.2.4	210 kg/cm2	222.22	222.22	do
	F.34/75/2023						213.33		
3.3	F.34/76/2023						231.11		
	F.34/77/2023	20-01-2024	17-02-2024	Wall Concrete	1.2.4	210 kg/cm2	226.67	228.15	do
	F.34/78/2023						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**