

NO.WRD/WDXI/SDIII/TECH/W.F.84/2024/2024-25/ 342 . Dated:-17/02/25

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah bank in Survey No. 7/0 at Potrem in ward No. 3 V.P. Bhati in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.84/06/2024						151.11		No. WRD/ SD I/ WD XII/ F. 47/ 530 /2024-25. DATED: 11-02-2025.
	F.84/07/2024	5/2/2025	12/2/2025	Foundation Ch. 0.00 m to 8.00m	1.2.4	140 kg/cm2	155.56	151.11	
	F.84/08/2024						146.67		
2	F.84/09/2024						160.00		
	F.84/10/2024	5/2/2025	12/2/2025	Foundation Ch. 8.00 m to 16.00m	1.2.4	140 kg/cm2	142.22	152.59	do
	F.84/11/2024						155.56		
3	F.84/12/2024						151.11		
	F.84/13/2024	6/2/2025	13-02-2025	1st Lift Ch. 0.00 m to 8.00 m	1.2.4	140 kg/cm2	137.78	145.19	do
	F.84/14/2024						146.67		
4	F.84/15/2024						142.22		
	F.84/16/2024	6/2/2025	13-02-2025	1st Lift Ch. 8.00 m to 16.00 m	1.2.4	140 kg/cm2	146.67	146.67	do
	F.84/17/2024						151.11		
5	F.84/18/2024						151.11		
	F.84/19/2024	7/2/2025	14-02-2025	2nd Lift Ch. 0.00 m to 8.00 m	1.2.4	140 kg/cm2	146.67	149.63	do
	F.84/20/2024						151.11		
6	F.84/21/2024						155.56		
	F.84/22/2024	7/2/2025	14-02-2025	2nd Lift Ch. 8.00 m to 16.00 m	1.2.4	140 kg/cm2	146.67	148.15	do
	F.84/23/2024						142.22		
7	F.84/24/2024						151.11		
	F.84/25/2024	10/2/2025	17-02-2025	3rd Lift Ch. 0.00 m to 16.00 m	1.2.4	140 kg/cm2	142.22	142.22	do
	F.84/26/2024						133.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER