

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the retaining wall of Kapileshwari nallah at Varkhand Haveli Junction in Ponda Taluka.

SAMPLE SENT BY: AE, SD II, WD III, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F. 31/14/2023						231.11		No.W.F. 31/SD II/WD III/
	F. 31/15/2023	15-01-2024	12/2/2024	foundation	1.2.4	210 kg/cm2	226.67	229.63	WRD/23-24/331.
	F. 31/16/2023						231.11		DATED: 20-01-2024
2	F. 31/17/2023						235.56		
	F. 31/18/2023	18-01-2024	15-02-2024	1st Lift	1.2.4	210 kg/cm2	217.78	228.15	do
	F. 31/19/2023						231.11		
3	F. 31/20/2023						231.11		
	F. 31/21/2023	19-01-2024	16-02-2024	2nd Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F. 31/22/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER