

NO.WRD/WDXI/SDIII/TECH/W.F.39/2023/2024-25/35

. Dated:-18/04/2024

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Stabilization of RHS of nallah bank at Shenviwada in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.39/10/2023						111.11		No. WRD/WD XI/ SD IV/ F CF/761/2023-24. DATED: 20-03-2024.
	F.39/11/2023	13-03-2024	10/4/2024	Foundation	1.3.6	100 kg/cm2	111.11	108.15	
	F.39/12/2023						102.22		
1.2	F.39/13/2023						115.56		
	F.39/14/2023	13-03-2024	10/4/2024	Foundation	1.3.6	100 kg/cm2	115.56	112.60	do
	F.39/15/2023						106.67		
1.3	F.39/16/2023						115.56		
	F.39/17/2023	13-03-2024	10/4/2024	Foundation	1.3.6	100 kg/cm2	111.11	109.63	do
	F.39/18/2023						102.22		
2	F.39/19/2023						106.67		
	F.39/20/2023	16-03-2024	15-04-2024	Horizontal Middle belt	1.3.6	100 kg/cm2	97.78	102.22	do
	F.39/21/2023						102.22		
3	F.39/22/2023						115.56		
	F.39/23/2023	19-03-2024	16-04-2024	Horizontal Top belt	1.3.6	100 kg/cm2	106.67	111.11	do
	F.39/24/2023						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER