

## GOVERNMENT OF GOA

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Annual maintenance repairs to the WC 6,7,8,9 at from outlet No. 19 of SIP canal for the year 2025-26 in Sanguem Constituency.

**SAMPLE SENT BY:** AE, SD III, WD X, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**07 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.48/05/2025						155.56		No. WRD/WD X/ SD III/
	F.48/06/2025	15-11-2025	22-11-2025	Canal lining PCC	1.2.4	140 kg/cm2	146.67	148.15	W.F. 09/201/2025-26.
	F.48/07/2025						142.22		<b>DATED: 17-11-2025</b>
1.2	F.48/08/2025						155.56		
	F.48/09/2025	15-11-2025	22-11-2025	Canal lining PCC	1.2.4	140 kg/cm2	146.67	149.63	
	F.48/10/2025						146.67		
1.3	F.48/11/2025						151.11		
	F.48/12/2025	15-11-2025	22-11-2025	Canal lining PCC	1.2.4	140 kg/cm2	146.67	148.15	
	F.48/13/2025						146.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**