

NO.WRD/WDXI/SDIII/TECH/W.F.45/2023/2023-24/390

. Dated:-05/03/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures to the nallah at Kanote - Sakharwal in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.45/35/2023						231.11		No. WRD/WD XI/ SD IV/ W.F 551/630/2023-24. DATED: 07-02-2024.
	F.45/36/2023	31-01-2024	28-02-2024	Foundation Ch. 0.00 m to 50.00 m	1.2.4	210 kg/cm2	222.22	226.67	
	F.45/37/2023						226.67		
1.2	F.45/38/2023						231.11		
	F.45/39/2023	31-01-2024	28-02-2024	Foundation Ch. 0.00 m to 50.00 m	1.2.4	210 kg/cm2	231.11	229.63	do
	F.45/40/2023						226.67		
2.1	F.45/41/2023						226.67		
	F.45/42/2023	1/2/2024	29-02-2024	Foundation Ch.50.00 m to 100.00 m	1.2.4	210 kg/cm2	235.56	232.60	do
	F.45/43/2023						235.56		
2.2	F.45/44/2023						231.11		
	F.45/45/2023	1/2/2024	29-02-2024	Foundation Ch.50.00 m to 100.00 m	1.2.4	210 kg/cm2	222.22	229.63	do
	F.45/46/2023						235.56		
3.1	F.45/47/2023						226.67		
	F.45/48/2023	2/2/2024	1/3/2024	Foundation Ch.100.00 m to 175 m	1.2.4	210 kg/cm2	235.56	225.19	do
	F.45/49/2023						213.33		
3.2	F.45/50/2023						231.11		
	F.45/51/2023	2/2/2024	1/3/2024	Foundation Ch.100.00 m to 175 m	1.2.4	210 kg/cm2	222.22	226.67	do
	F.45/52/2023						226.67		
3.3	F.45/53/2023						226.67		
	F.45/54/2023	2/2/2024	1/3/2024	Foundation Ch.100.00 m to 175 m	1.2.4	210 kg/cm2	231.11	229.63	do
	F.45/55/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures to the nallah at Kanote - Sakharwal in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
4.1	F.45/56/2023						226.67		No. WRD/WD XI/ SD IV/
	F.45/57/2023	6/2/2024	5/3/2024	Horizontal middle band	1.2.4	210 kg/cm ²	226.67	223.71	W.F 551/630/2023-24.
	F.45/58/2023						217.78		DATED: 07-02-2024.
4.2	F.45/59/2023						226.67		
	F.45/60/2023	6/2/2024	5/3/2024	Horizontal middle band	1.2.4	210 kg/cm ²	231.11	226.67	do
	F.45/61/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.45/2023/2023-24/402

. Dated:-11/3/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures to the nallah at Kanote - Sakharwal in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.45/65/2023						231.11		No. WRD/WD XI/ SD IV/
	F.45/66/2023	10/2/2024	11/3/2024	Horizontal Top band	1.2.4	210 kg/cm ²	231.11	229.63	W.F 551/651/2023-24.
	F.45/67/2023						226.67		DATED: 17-02-2024.
5.2	F.45/68/2023						235.56		
	F.45/69/2023	10/2/2024	11/3/2024	Horizontal Top band	1.2.4	210 kg/cm ²	231.11	232.59	do
	F.45/70/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER