

NO.WRD/WDXI/SDIII/TECH/W.F.42/2023/2023-24/391

. Dated:-5/2/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Vazangal V.P. Shiroda in Shiroda Constituency of Taluka Ponda.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.42/11/2023						226.67		No. WRD/WD XI/ SD IV/ W.F 502/673/2023-24. DATED: 27-02-2024.
	F.42/12/2023	30-01-2024	27-02-2024	Bed PCC	1.2.4	210 kg/cm2	231.11	228.15	
	F.42/13/2023						226.67		
1.2	F.42/14/2023						222.22		do
	F.42/15/2023	30-01-2024	27-02-2024	Bed PCC	1.2.4	210 kg/cm2	235.56	228.15	
	F.42/16/2023						226.67		
2.1	F.42/17/2023						235.56		do
	F.42/18/2023	31-01-2024	28-02-2024	Foundation	1.2.4	210 kg/cm2	217.78	228.15	
	F.42/19/2023						231.11		
2.2	F.42/20/2023						240.00		do
	F.42/21/2023	31-01-2024	28-02-2024	Foundation	1.2.4	210 kg/cm2	231.11	226.67	
	F.42/22/2023						208.89		
2.3	F.42/23/2023						226.67		do
	F.42/24/2023	31-01-2024	28-02-2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.42/25/2023						231.11		
2.4	F.42/26/2023						226.67		do
	F.42/27/2023	31-01-2024	28-02-2024	Foundation	1.2.4	210 kg/cm2	235.56	228.15	
	F.42/28/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Vazangal V.P. Shiroda in Shiroda Constituency of Taluka Ponda.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.42/29/2023						240.00		No. WRD/WD XI/ SD IV/ W.F 502/673/2023-24. DATED: 27-02-2024.
	F.42/30/2023	1/2/2024	29-02-2024	Foundation	1.2.4	210 kg/cm2	222.22	231.11	
	F.42/31/2023						231.11		
3.2	F.42/32/2023						231.11		
	F.42/33/2023	1/2/2024	29-02-2024	Foundation	1.2.4	210 kg/cm2	235.56	228.15	do
	F.42/34/2023						217.78		
3.3	F.42/35/2023						235.56		
	F.42/36/2023	1/2/2024	29-02-2024	Foundation	1.2.4	210 kg/cm2	222.22	229.63	do
	F.42/37/2023						231.11		
3.4	F.42/38/2023						240.00		
	F.42/39/2023	1/2/2024	29-02-2024	Foundation	1.2.4	210 kg/cm2	231.11	232.59	do
	F.42/40/2023						226.67		
4.1	F.42/41/2023						284.44		
	F.42/42/2023	2/2/2024	1/3/2024	Foundation	1.1.5.3	265 kg/cm2	293.33	282.96	do
	F.42/43/2023						271.11		
4.2	F.42/44/2023						275.56		
	F.42/45/2023	2/2/2024	1/3/2024	Foundation	1.1.5.3	265 kg/cm2	288.89	281.48	do
	F.42/46/2023						280.00		
4.3	F.42/47/2023						297.78		
	F.42/48/2023	2/2/2024	1/3/2024	Foundation	1.1.5.3	265 kg/cm2	288.89	288.89	do
	F.42/49/2023						280.00		
4.4	F.42/50/2023						284.44		
	F.42/51/2023	2/2/2024	1/3/2024	Foundation	1.1.5.3	265 kg/cm2	288.89	284.44	do
	F.42/52/2023						280.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Vazangal V.P. Shiroda in Shiroda Constituency of Taluka Ponda.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.42/53/2023						293.33		No. WRD/WD XI/ SD IV/ W.F 502/673/2023-24. DATED: 27-02-2024.
	F.42/54/2023	3/2/2024	2/3/2024	Foundation	1.1.5.3	265 kg/cm2	288.89	284.44	
	F.42/55/2023						271.11		
5.2	F.42/56/2023						288.89		do
	F.42/57/2023	3/2/2024	2/3/2024	Foundation	1.1.5.3	265 kg/cm2	280.00	287.41	
	F.42/58/2023						293.33		
5.3	F.42/59/2023						266.67		do
	F.42/60/2023	3/2/2024	2/3/2024	Foundation	1.1.5.3	265 kg/cm2	293.33	285.93	
	F.42/61/2023						297.78		
5.4	F.42/62/2023						275.56		do
	F.42/63/2023	3/2/2024	2/3/2024	Foundation	1.1.5.3	265 kg/cm2	288.89	287.41	
	F.42/64/2023						297.78		
6.1	F.42/65/2023						280.00		do
	F.42/66/2023	5/2/2024	4/3/2024	Wall	1.1.5.3	265 kg/cm2	284.44	285.92	
	F.42/67/2023						293.33		
6.2	F.42/68/2023						288.89		do
	F.42/69/2023	5/2/2024	4/3/2024	Wall	1.1.5.3	265 kg/cm2	297.78	287.41	
	F.42/70/2023						275.56		
6.3	F.42/71/2023						284.44		do
	F.42/72/2023	5/2/2024	4/3/2024	Wall	1.1.5.3	265 kg/cm2	262.22	281.48	
	F.42/73/2023						297.78		
6.4	F.42/74/2023						271.11		do
	F.42/75/2023	5/2/2024	4/3/2024	Wall	1.1.5.3	265 kg/cm2	288.89	284.44	
	F.42/76/2023						293.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.42/2023/2023-24/ 15

. Dated:-4/4/24

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Vazangal V.P. Shiroda in Shiroda Constituency of Taluka Ponda.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.42/89/2023						231.11		No. WRD/WD XI/ SD IV/
	F.42/90/2023	4/3/2024	1/4/2024	Horizontal middle belt	1.2.4	210 kg/cm2	235.56	228.15	W.F 502/ 712 (A) /2023-24.
	F.42/91/2023						217.78		DATED: 11-03-2024.
2	F.42/92/2023						280.00		
	F.42/93/2023	5/3/2024	2/4/2024	Wall	1.1.5.3	265 kg/cm2	284.44	285.92	do
	F.42/94/2023						293.33		
3	F.42/95/2023						293.33		
	F.42/96/2023	6/3/2024	3/4/2024	Wall	1.1.5.3	265 kg/cm2	288.89	284.44	do
	F.42/97/2023						271.11		
4	F.42/98/2023						235.56		
	F.42/99/2023	7/3/2024	4/4/2024	Horizontal top belt	1.2.4	210 kg/cm2	222.22	229.63	do
	F.42/100/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER