

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the existing nallah behind St.Cruz Chapel at Malbhat in Margao Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.48/06/2023						235.56		No. 335/ SD III/ WD III/ WRD/23-24/554. <b>DATED: 18-03-2024</b>
	F.48/07/2023	20-02-2024	19-03-2024	Nallah Fdn Ch. 0 to 65 m	1.2.4	210 kg/cm2	226.67	228.15	
	F.48/08/2023						222.22		
1.2	F.48/09/2023						231.11		
	F.48/10/2023	20-02-2024	19-03-2024	Nallah Fdn Ch. 0 to 65 m	1.2.4	210 kg/cm2	222.22	226.67	do
	F.48/11/2023						226.67		
2.1	F.48/12/2023						280.00		
	F.48/13/2023	24-02-2024	23-03-2024	Nallah Raft Ch. 0 m to 30 m	1.1.5.3	265 kg/cm2	284.44	281.48	do
	F.48/14/2023						280.00		
2.2	F.48/15/2023						293.33		
	F.48/16/2023	24-02-2024	23-03-2024	Nallah Raft Ch. 0 m to 30 m	1.1.5.3	265 kg/cm2	280.00	284.44	do
	F.48/17/2023						280.00		
3.1	F.48/18/2023						288.89		
	F.48/19/2023	1/3/2024	29-03-2024	Nallah Raft Ch. 30 m to 65 m	1.1.5.3	265 kg/cm2	284.44	284.44	do
	F.48/20/2023						280.00		
3.2	F.48/21/2023						288.89		
	F.48/22/2023	1/3/2024	29-03-2024	Nallah Raft Ch. 30 m to 65 m	1.1.5.3	265 kg/cm2	288.89	285.93	do
	F.48/23/2023						280.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of protection wall to the existing nallah behind St.Cruz Chapel at Malbhat in Margao Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.48/24/2023						293.33		No. 335/ SD III/ WD III/ WRD/23-24/554. <b>DATED: 18-03-2024</b>
	F.48/25/2023	5/3/2024	2/4/2024	Nallah walls Ch. 0 m to 20 m	1.1.5.3	265 kg/cm2	280.00	285.92	
	F.48/26/2023						284.44		
4.2	F.48/27/2023						284.44		do
	F.48/28/2023	5/3/2024	2/4/2024	Nallah walls Ch. 0 m to 20 m	1.1.5.3	265 kg/cm2	284.44	282.96	
	F.48/29/2023						280.00		
5.1	F.48/30/2023						284.44		do
	F.48/31/2023	12/3/2024	10/4/2024	Nallah walls Ch. 20 m to 40 m	1.1.5.3	265 kg/cm2	284.44	287.40	
	F.48/32/2023						293.33		
5.2	F.48/33/2023						275.56		do
	F.48/34/2023	12/3/2024	10/4/2024	Nallah walls Ch. 20 m to 40 m	1.1.5.3	265 kg/cm2	280.00	282.96	
	F.48/35/2023						293.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**NO.WRD/WDXI/SDIII/TECH/W.F.48/2023/2023-24/41**

**. Dated:-19/04/24**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the existing nallah behind St.Cruz Chapel at Malbhat in Margao Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
6.1	F.48/36/2023						284.44		No. 335/ SD III/ WD III/
	F.48/37/2023	16-03-2024	13-04-2024	Nallah walls Ch. 40 m to 55 m	1.1.5.3	265 kg/cm <sup>2</sup>	284.44	282.96	WRD/23-24/561.
	F.48/38/2023						280.00		<b>DATED: 26-03-2024</b>
6.2	F.48/39/2023						280.00		
	F.48/40/2023	16-03-2024	13-04-2024	Nallah walls Ch. 40 m to 55 m	1.1.5.3	265 kg/cm <sup>2</sup>	284.44	281.48	do
	F.48/41/2023						280.00		
7.1	F.48/42/2023						293.33		
	F.48/43/2023	19-03-2024	16-04-2024	Nallah walls Ch. 55 m to 65 m	1.1.5.3	265 kg/cm <sup>2</sup>	280.00	285.92	do
	F.48/44/2023						284.44		
7.2	F.48/45/2023						293.33		
	F.48/46/2023	19-03-2024	16-04-2024	Nallah walls Ch. 55 m to 65 m	1.1.5.3	265 kg/cm <sup>2</sup>	280.00	284.44	do
	F.48/47/2023						280.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**