

NO.WRD/WDXI/SDIII/TECH/W.F.84/2024/2024-25/ 404

Dated:-10/03/25

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah bank in Survey No. 7/0 at Potrem in ward No. 3 V.P. Bhati in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.84/27/2024						231.11		No. WRD/ SD I/ WD XII/ F. 47/ 530 /2024-25. DATED: 11-02-2025.
	F.84/28/2024	5/2/2025	5/3/2025	Foundation Ch. 0.00 m to 8.00m	1.2.4	210 kg/cm2	226.67	228.15	
	F.84/29/2024						226.67		
2	F.84/30/2024						235.56		
	F.84/31/2024	5/2/2025	5/3/2025	Foundation Ch. 8.00 m to 16.00m	1.2.4	210 kg/cm2	226.67	229.63	do
	F.84/32/2024						226.67		
3	F.84/33/2024						231.11		
	F.84/34/2024	6/2/2025	6/3/2025	1st Lift Ch. 0.00 m to 8.00 m	1.2.4	210 kg/cm2	235.56	231.11	do
	F.84/35/2024						226.67		
4	F.84/66/2024						235.56		
	F.84/37/2024	6/2/2025	6/3/2025	1st Lift Ch. 8.00 m to 16.00 m	1.2.4	210 kg/cm2	222.22	232.59	do
	F.84/38/2024						240.00		
5	F.84/49/2024						235.56		
	F.84/40/2024	7/2/2025	7/3/2025	2nd Lift Ch. 0.00 m to 8.00 m	1.2.4	210 kg/cm2	231.11	228.15	do
	F.84/41/2024						217.78		
6	F.84/42/2024						235.56		
	F.84/43/2024	7/2/2025	7/3/2025	2nd Lift Ch. 8.00 m to 16.00 m	1.2.4	210 kg/cm2	235.56	229.63	do
	F.84/44/2024						217.78		
7	F.84/45/2024						231.11		
	F.84/46/2024	10/2/2025	10/3/2025	3rd Lift Ch. 0.00 m to 16.00 m	1.2.4	210 kg/cm2	235.56	229.63	do
	F.84/47/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER