

NO.WRD/WDXI/SDIII/TECH/W.F.69/2023/2023-24/ 412

. Dated:-14/03/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the right bank of nallah at Deulwada in Village Betoda of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | TARGET STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|--------------|--------------|--------------|--------------------|------------------|--------------------|-----------------------|---------------------|---|
| 1 | F.69/11/2023 | | | | | | 146.67 | | No. WRD/WD XI/ SD IV/ W.F 598/ 708 /2023-24. DATED: 08-03-2024. |
| | F.69/12/2023 | 2/3/2024 | 9/3/2024 | Side Wall | 1.2.4 | 140 kg/cm2 | 151.11 | 146.67 | |
| | F.69/13/2023 | | | | | | 142.22 | | |
| 2 | F.69/14/2023 | | | | | | 146.67 | | |
| | F.69/15/2023 | 4/3/2024 | 11/3/2024 | Platform | 1.2.4 | 140 kg/cm2 | 137.78 | 143.71 | do |
| | F.69/16/2023 | | | | | | 146.67 | | |
| 3 | F.69/17/2023 | | | | | | 146.67 | | |
| | F.69/18/2023 | 6/3/2024 | 13-03-2024 | Platform | 1.2.4 | 140 kg/cm2 | 142.22 | 143.70 | do |
| | F.69/19/2023 | | | | | | 142.22 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER