

NO.WRD/WDXI/SDIII/TECH/W.F.42/2023/2023-24/ 413

. Dated:-14/03/24

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to nallah bank at Vazangal V.P. Shiroda in Shiroda Constituency of Taluka Ponda.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**07 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.42/77/2023						146.67		No. WRD/WD XI/ SD IV/ W.F 502/ <b>712 (A)</b> /2023-24. <b>DATED: 11-03-2024.</b>
	F.42/78/2023	4/3/2024	11/3/2024	Horizontal middle belt	1.2.4	140 kg/cm2	142.22	142.22	
	F.42/79/2023						137.78		
2	F.42/80/2023						186.67		do
	F.42/81/2023	5/3/2024	12/3/2024	Wall	1.1.5.3	175 kg/cm2	191.11	186.67	
	F.42/82/2023						182.22		
3	F.42/83/2023						191.11		do
	F.42/84/2023	6/3/2024	13-03-2024	Wall	1.1.5.3	175 kg/cm2	177.78	188.15	
	F.42/85/2023						195.56		
4	F.42/86/2023						151.11		do
	F.42/87/2023	7/3/2024	14-03-2024	Horizontal top belt	1.2.4	140 kg/cm2	142.22	146.67	
	F.42/88/2023						146.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**