

NO: WRD /WD XI / SD III/ TECH/W.F. 47-Oct-2022/42 / 2022-23

Dated:12/04/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Protection to nallah bank in survey No.161/1 V.P. Querim in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.47/42/2022						235.56		No. WRD/WD XI/SD IV/ F.CV/604/2022-23. DATED: 15-03-2023.
	F.47/43/2022	9/3/2023	6/4/2023	for foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.47/44/2022						222.22		
1.2	F.47/45/2022						231.11		
	F.47/46/2022	9/3/2023	6/4/2023	for foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F.47/47/2022						235.56		
2.1	F.47/48/2022						235.56		
	F.47/49/2022	10/3/2023	10/4/2023	for foundation	1.2.4	210 kg/cm2	240.00	237.04	do
	F.47/50/2022						235.56		
3.1	F.47/51/2022						235.56		
	F.47/52/2022	11/3/2023	10/4/2023	for foundation	1.2.4	210 kg/cm2	235.56	234.08	do
	F.47/53/2022						231.11		
4.1	F.47/54/2022						240.00		
	F.47/55/2022	12/3/2023	10/4/2023	Above foundation	1.2.4	210 kg/cm2	240.00	238.52	do
	F.47/56/2022						235.56		
4.2	F.47/57/2022						244.44		
	F.47/58/2022	12/3/2023	10/4/2023	Above foundation	1.2.4	210 kg/cm2	240.00	240.00	do
	F.47/59/2022						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Protection to nallah bank in survey No.161/1 V.P. Querim in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.47/60/2022						235.56		No. WRD/WD XI/SD IV/ F.CV/604/2022-23. DATED: 15-03-2023.
	F.47/61/2022	13/3/2023	10/4/2023	Above foundation	1.2.4	210 kg/cm2	231.11	232.59	
	F.47/62/2022						231.11		
5.2	F.47/63/2022						231.11		
	F.47/64/2022	13/3/2023	10/4/2023	Above foundation	1.2.4	210 kg/cm2	217.78	228.15	do
	F.47/65/2022						235.56		
6.1	F.47/66/2022						226.67		
	F.47/67/2022	14/3/2023	11/4/2023	Above foundation	1.2.4	210 kg/cm2	222.22	223.70	do
	F.47/68/2022						222.22		
6.2	F.47/69/2022						226.67		
	F.47/70/2022	14/3/2023	11/4/2023	Above foundation	1.2.4	210 kg/cm2	231.11	225.19	do
	F.47/71/2022						217.78		
7.1	F.47/72/2022						235.56		
	F.47/73/2022	15/3/2023	12/4/2023	Above foundation	1.2.4	210 kg/cm2	222.22	223.70	do
	F.47/74/2022						213.33		
7.2	F.47/75/2022						231.11		
	F.47/76/2022	15/3/2023	12/4/2023	Above foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.47/77/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER