

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall behind Mystical Rose Apartment in Sy.No. 19/5 in V.P. Davorlim Dicarpace in Velim Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Fatorda- Goa.

| NAME OF THE AGENCY | | | | TESTING PERIOD | | 28 days. | | | |
|--------------------|---------------|--------------|--------------|--------------------|------------------|--------------------|-----------------------|---------------------|--|
| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | TARGET STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
| 1.1 | F. 93/05/2024 | | | | | | 231.11 | | No. WRD/SD III/WD II/ F. 77/367/24-25. DATED: 12-03-2025. |
| | F. 93/06/2024 | 18-02-2025 | 18-03-2025 | | 1.2.4 | 210 kg/cm2 | 231.11 | 229.63 | |
| | F. 93/07/2024 | | | | | | 226.67 | | |
| 1.2 | F. 93/08/2024 | | | | | | 235.56 | | do |
| | F. 93/09/2024 | 18-02-2025 | 18-03-2025 | | 1.2.4 | 210 kg/cm2 | 231.11 | 231.11 | |
| | F. 93/10/2024 | | | | | | 226.67 | | |
| 1.3 | F. 93/11/2024 | | | | | | 235.56 | | do |
| | F. 93/12/2024 | 18-02-2025 | 18-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 228.15 | |
| | F. 93/13/2024 | | | | | | 222.22 | | |
| 2.1 | F. 93/14/2024 | | | | | | 222.22 | | do |
| | F. 93/15/2024 | 20-02-2025 | 20-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 226.67 | |
| | F. 93/16/2024 | | | | | | 231.11 | | |
| 2.2 | F. 93/17/2024 | | | | | | 235.56 | | do |
| | F. 93/18/2024 | 20-02-2025 | 20-03-2025 | | 1.2.4 | 210 kg/cm2 | 217.78 | 228.15 | |
| | F. 93/19/2024 | | | | | | 231.11 | | |
| 2.3 | F. 93/20/2024 | | | | | | 240.00 | | do |
| | F. 93/21/2024 | 20-02-2025 | 20-03-2025 | | 1.2.4 | 210 kg/cm2 | 231.11 | 228.15 | |
| | F. 93/22/2024 | | | | | | 213.33 | | |
| 3.1 | F. 93/23/2024 | | | | | | 235.56 | | do |
| | F. 93/24/2024 | 21-02-2025 | 21-03-2025 | | 1.2.4 | 210 kg/cm2 | 231.11 | 229.63 | |
| | F. 93/25/2024 | | | | | | 222.22 | | |
| 3.2 | F. 93/26/2024 | | | | | | 231.11 | | do |
| | F. 93/27/2024 | 21-02-2025 | 21-03-2025 | | 1.2.4 | 210 kg/cm2 | 222.22 | 226.67 | |
| | F. 93/28/2024 | | | | | | 226.67 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall behind Mystical Rose Appartment in Sy.No. 19/5 in V.P. Davorlim Dicarvale in Velim Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Fatorda- Goa.

| NAME OF THE AGENCY | | | | TESTING PERIOD | | 28 days. | | LETTER No / DATED | |
|--------------------|---------------|--------------|--------------|--------------------|---------------|-----------------|--------------------|-------------------|--|
| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | TARGET STRENGTH | Comp sth in Kg/cm2 | | Avg. Comp Kg/cm2 |
| 3.3 | F. 93/29/2024 | | | | | | 226.67 | | No. WRD/SD III/WD II/ F. 77/367/24-25. DATED: 12-03-2025. |
| | F. 93/30/2024 | 21-02-2025 | 21-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 225.19 | |
| | F. 93/31/2024 | | | | | | 222.22 | | |
| 4.1 | F. 93/32/2024 | | | | | | 231.11 | | |
| | F. 93/33/2024 | 22-02-2025 | 22-03-2025 | | 1.2.4 | 210 kg/cm2 | 235.56 | 226.67 | do |
| | F. 93/34/2024 | | | | | | 213.33 | | |
| 4.2 | F. 93/35/2024 | | | | | | 222.22 | | |
| | F. 93/36/2024 | 22-02-2025 | 22-03-2025 | | 1.2.4 | 210 kg/cm2 | 235.56 | 228.15 | do |
| | F. 93/37/2024 | | | | | | 226.67 | | |
| 4.3 | F. 93/38/2024 | | | | | | 231.11 | | |
| | F. 93/39/2024 | 22-02-2025 | 22-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 225.19 | do |
| | F. 93/40/2024 | | | | | | 217.78 | | |
| 5.1 | F. 93/41/2024 | | | | | | 217.78 | | |
| | F. 93/42/2024 | 24-02-2025 | 24-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 226.67 | do |
| | F. 93/43/2024 | | | | | | 235.56 | | |
| 5.2 | F. 93/44/2024 | | | | | | 231.11 | | |
| | F. 93/45/2024 | 24-02-2025 | 24-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 228.15 | do |
| | F. 93/46/2024 | | | | | | 226.67 | | |
| 6.1 | F. 93/47/2024 | | | | | | 244.44 | | |
| | F. 93/48/2024 | 25-02-2025 | 25-03-2025 | | 1.2.4 | 210 kg/cm2 | 222.22 | 231.11 | do |
| | F. 93/49/2024 | | | | | | 226.67 | | |
| 6.3 | F. 93/50/2024 | | | | | | 231.11 | | |
| | F. 93/51/2024 | 25-02-2025 | 25-03-2025 | | 1.2.4 | 210 kg/cm2 | 235.56 | 231.11 | do |
| | F. 93/52/2024 | | | | | | 226.67 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall behind Mystical Rose Appartment in Sy.No. 19/5 in V.P. Davorlim Dicarvale in Velim Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Fatorda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | TARGET STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|---------------|--------------|--------------|--------------------|------------------|--------------------|-----------------------|---------------------|---------------------------|
| 6.3 | F. 93/53/2024 | | | | | | 235.56 | | No. WRD/SD III/WD II/ |
| | F. 93/54/2024 | 25-02-2025 | 25-03-2025 | | 1.2.4 | 210 kg/cm2 | 226.67 | 229.63 | F. 77/367/24-25. |
| | F. 93/55/2024 | | | | | | 226.67 | | DATED: 12-03-2025. |

JUNIOR ENGINEER.

ASSISTANT ENGINEER